

Reopening Swimming Pools after a Power Outage

During a power outage, pool water cannot be circulated or disinfected. Harmful bacteria may grow in the stagnant water, and could pose a health risk to your clients.

Steps to reopening your pool basins after a power outage

1. Superchlorinate your pool water to at least 10 ppm free chlorine.
2. Circulate the pool water for at least one (1) turn over period.
3. Rebalance the pool water chemistry.
4. Submit a bacteriological water sample.
5. Confirm with your local public health inspector that your bacteriological water sample was satisfactory.
6. Reopen to the public.

If your swimming pool was contaminated by flood water, please review information available at www.albertahealthservices.ca/flood.

Contact us at 1-833-476-4743 or [submit a request online](#) at ahs.ca/eph.

PUB-0741-201306

©2013 Alberta Health Services, Safe Healthy Environments



This work is licensed under a [Creative Commons Attribution-Non-commercial-Share Alike 4.0 International license](http://creativecommons.org/licenses/by-nc-sa/4.0/). You are free to copy, distribute and adapt the work for non-commercial purposes, as long as you attribute the work to Alberta Health Services and abide by the other license terms. If you alter, transform, or build upon this work, you may distribute the resulting work only under the same, similar, or compatible license. The license does not apply to content for which the Alberta Health Services is not the copyright owner.

This material is intended for general information only and is provided on an "as is," "where is" basis. Although reasonable efforts were made to confirm the accuracy of the information, Alberta Health Services does not make any representation or warranty, express, implied or statutory, as to the accuracy, reliability, completeness, applicability or fitness for a particular purpose of such information.