

ORDER OF AN EXECUTIVE OFFICER

To: Govind and Vidya Reddy; Stacy Martin; Tim Closs; 1058250 Alberta Ltd

RE: Those housing premises located in Lethbridge, Alberta and municipally described as:
226 McGill Boulevard W – Unit D.

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. There are missing transition strips in the flooring of the kitchen and bathroom.
- b. There are missing baseboards.
- c. There are vent covers that have not been installed.
- d. The railing on the stairs does not have any guard balusters.
- e. The smoke alarm is not working.
- f. The kitchen cupboard doors were removed for repairs and have never been replaced.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Housing Regulation, Alberta Regulation 173/99, and the Minimum Housing and Health Standards exist in and about the above noted premises, namely:

- a. There are missing transition strips in the flooring of the kitchen and bathroom which is in contravention of section III(5) of the Minimum Housing and Health Standards which states that: All walls, windows, ceilings, floors, and floor coverings shall be maintained in good repair, free of cracks, holes, loose or lifting coverings and in a condition that renders it easy to clean.
- b. There are missing baseboards which is in contravention of section III(5) of the Minimum Housing and Health Standards which states that: All walls, windows, ceilings, floors, and floor coverings shall be maintained in good repair, free of cracks, holes, loose or lifting coverings and in a condition that renders it easy to clean.
- c. There are vent covers that have not been installed which is in contravention of section III(5) of the Minimum Housing and Health Standards which states that: All walls, windows, ceilings, floors, and floor coverings shall be maintained in good repair, free of cracks, holes, loose or lifting coverings and in a condition that renders it easy to clean.

- d. The railing on the stairs does not have any guard balusters which is in contravention of section III(3)(c) of the Minimum Housing and Health Standards which states that: Inside or outside stairs or porches including all treads, risers, supporting structural members, rails, guards and balconies, shall be maintained in good repair and shall comply with the requirements of the Alberta Building Code or a Professional Engineer design.
- e. The smoke alarm is not working which is in contravention of section IV(12)(a) of the Minimum Housing and Health Standards which states that: Smoke alarms shall be operational and in good repair at all times.
- f. The kitchen cupboard doors were removed for repairs and have never been replaced which is in contravention of section IV(14)(a)(iii) of the Minimum Housing and Health Standards which states that: Every housing premises shall be provided with a food preparation area, which includes: a counter or table used for food preparation which shall be of sound construction and furnished with surfaces that are easily cleaned.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Install flooring transition strips and ensure flooring is easily cleanable and in good repair.
 - b. Ensure baseboards are installed wherever they are necessary.
 - c. Ensure vent covers are properly installed.
 - d. Ensure guardrails are installed as per the Alberta Building Code requirements.
 - e. Ensure smoke alarm is working.
 - f. Ensure cupboard doors are replaced and installed correctly.
2. The work referred to in paragraph 1 shall be completed by March 1st, 2017.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Lethbridge, Alberta, January 18, 2017.

Mark Albiez BSc, BEH(AD), CPHI(C)
Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, Telus Plaza North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <http://www.health.alberta.ca/about/PHAB.html>

A Notice of Appeal form may be obtained by contacting Alberta Health Services at 780-342-0122 or by contacting the Public Health Appeal Board.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or www.qp.gov.ab.ca.

Health Legislation and regulations are available for purchase. Please contact Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or www.qp.gov.ab.ca.

Copies of standards are available by contacting the Health Protection Branch of Alberta Health at 780-427-4518 or by visiting: www.health.alberta.ca/about/health-legislation.html

Template revised December 13, 2016