

ORDER OF AN EXECUTIVE OFFICER Boil Water Order

To: Daniel O'Neil
"the owner"

RE: The Drinking Water Supply located in Mountain View County, Alberta and municipally described as: NE 7-29-5-W5M, Block 1, Lot 1

WHEREAS I, an **Executive Officer of Alberta Health Services**, have inspected the above noted drinking water supply pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted drinking water supply which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. A bacteriological water sample taken from the rental house kitchen tap on February 24, 2015, was positive for Total Coliforms.
- b. A bacteriological water sample taken from the rental house kitchen tap on February 27, 2015, showed 1 Total Coliform/100mL.
- c. A bacteriological water sample taken from the shop kitchen tap on February 27, 2015, showed 1 Total Coliform/100mL.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in and about the above noted Drinking Water Supply, namely:

- a. A bacteriological water sample taken from the rental house kitchen tap on February 24, 2015, was positive for Total Coliforms, which is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states "Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable".
- b. A bacteriological water sample taken from the rental house kitchen tap on February 27, 2015, showed 1 Total Coliform/100mL, which is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states "Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable".
- c. A bacteriological water sample taken from the shop kitchen tap on February 27, 2015, showed 1 Total Coliform/100mL, which states "Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable".

AND WHEREAS by virtue of the foregoing, the above noted Drinking Water Supply is hereby declared **unfit for human consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the owner immediately undertake and diligently pursue the completion of the following work in and about the above noted drinking water supply, namely:
 - a. Issue a Boil Water Advisory to all users of the above noted Drinking Water Supply, instructing them to boil the water for a minimum of one minute prior to ingesting.
 - b. Provide bottled water or water from another source that is approved by Alberta Health Services for all users to drink and cook with.
 - c. Treat the system as necessary to render the water supply potable, AND submit water samples to the Provincial Laboratory for microbiological analysis at least weekly from April to October, and at least monthly from November to March.
2. The work referred to above in paragraph 1a and 1b shall be completed immediately.
3. The work referred to in paragraph 1c shall be completed by March 13, 2015.
4. Until such time as the work referred to in paragraph 1 is completed to the satisfaction of the undersigned, or an executive officer of Alberta Health Services, this order shall remain in effect.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Airdrie, Alberta, March 6, 2015.

Confirmation of a verbal order issued to Dan O'Neil, on March 3, 2015.

Carol Brittain, CPHI(C)
Executive Officer
Alberta Health Services

YOU HAVE THE RIGHT TO APPEAL

A person who a) is directly affected by a decision of a Regional Health Authority, and
b) feels himself aggrieved by the decision

may appeal the decision within ten (10) days after receiving the order to the Public Health Appeal Board located at Reception, Main Floor. Telus Plaza, 10025 Jasper Avenue, Edmonton, Alberta, T5J 1S6, Telephone 780-427-2813 Fax 780-422-0914.

The terms of this Order remain in effect notwithstanding the filing or proposed filing of any such appeal. If you appeal, you may also make an application to the Board for a stay of this Order pending the appeal.

A copy of the Public Health Appeal form may be obtained by contacting Alberta Health Services at 780-342-0122 or the Public Health Appeal Board 780-427-2813.

You are advised that all orders remain in effect pending such an appeal

HEALTH LEGISLATION, REGULATIONS AND STANDARDS

Electronic versions of the Public Health Act and Regulations are available at the Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or www.qp.gov.ab.ca.

Health Legislation and regulations are available for purchase. Please contact Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or www.qp.gov.ab.ca.

Copies of standards are available by contacting the Health Protection Branch of Alberta Health at 780-427-4518, or by visiting: www.health.alberta.ca/about/health-legislation.html

AIRDRIE Regional Health Centre

604 Main Street South
Airdrie, AB T4B 3K7
Phone: 403-912-8400
Fax: 403-912-8410

BANFF Health Unit

303 Lynx Street
PO Box 1266
Banff, AB T1L 1B3
Phone: 403-762-2990
Fax: 403-762-5570

CALGARY - Southport Atrium

10101 Southport Road SW
Calgary, AB T2W 3N2
Phone: 403-943-2288
Fax: 403-943-8056

CANMORE Public Health

#104, 800 Railway Avenue
Canmore, AB T1W 1P1
Phone: 403-678-5656
Fax: 403-678-5068

CLARESHOLM Health Unit

5221 2nd Street W
PO Box 1391
Claresholm, AB T0L 0T0
Phone: 403 625-4061
Fax: 403-625-4062

COCHRANE Community Health Centre

60 Grande Boulevard
Cochrane, AB T4C 0S4
Phone: 403-851-6000
Fax: 403-851-6009

OKOTOKS Health and Wellness Centre

11 Cimarron Common
Okotoks, AB T1S 2E9
Phone: 403-995-2600
Fax: 403-995-2639

STRATHMORE Public Health Office

650 Westchester Road
Strathmore, AB T1P 1H8
Phone: 403-361-7200
Fax: 403-361-7244