

ORDER OF AN EXECUTIVE OFFICER UNFIT FOR HUMAN HABITATION ORDER TO VACATE

To: 926770 Alberta LTD.
“the Owner”

Karamjit Johal
“the Owner”

Ankar Johal
“the Property Manager”

Cindy Schofield
“the Property Manager”

And To: All Occupant(s) of the following Housing premises: 4313R 84 Street NE – Northshore Camper 31SB 2006 V240-25

RE: Those housing premises located in Calgary, Alberta and municipally described as:
4313R 84 Street NE – Northshore Camper 31SB 2006 V240-25

WHEREAS I, an **Executive Officer of Alberta Health Services**, have inspected the above noted premises pursuant to the provisions of the **Public Health Act**, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. There was no running water available in the suite.
- b. The toilet was not operational.
- c. There were numerous buckets of human waste observed outside near the suite.
- d. The ambient temperature of the suite measured between 6-12 degrees Celsius.
- e. The openable area in the bedroom window measured approximately 17 inches high and 14 inches wide, which is too small for emergency egress requirements.
- f. There were electrical wires hanging from the kitchen ceiling.
- g. The smoke alarm installed was not operational.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Housing Regulation, Alberta Regulation 173/99, and the Minimum Housing and Health Standards, and the Nuisance and General Sanitation Regulation, 2003, exist in and about the above noted premises, namely:

- a. There was no running water available in the suite. This is a contravention of section IV(9) of the Minimum Housing and Health Standards which states that: Every building used in whole or in part, as housing premises shall be supplied with a potable water supply of sufficient volume, pressure and temperature to serve the needs of the inhabitants.
- b. The toilet was not operational. This is a contravention of section IV(6)(b) of the Minimum Housing and Health Standards which states that: Adequate water volume and pressure shall be provided to ensure the proper operation and flushing of all fixtures. This is also a contravention of section IV(6)(a) of the Minimum Housing and Health Standards which states that: The plumbing system and the sanitary drainage system or private sewage disposal system, as the case may be, including drains, fixtures, traps, vents, stacks, waste disposal facilities, pumpout sewage holding tanks, septic tanks and the disposal system shall be maintained in a proper operating condition.
- c. There were numerous buckets of human waste observed outside near the suite. This is a contravention of section IV(6) of the Minimum Housing and Health Standards which states that: Every housing premises shall be connected to the public sewage system, or to an approved private sewage disposal system. This is also a contravention of section 2(1) of the Public Health Act Nuisance and General Sanitation Regulation, 2003 which states that: No person shall create, commit or maintain a nuisance.
- d. The ambient temperature of the office suite measured between 6-12 degrees Celsius. This is a contravention of section IV(8)(a)(i) of the Minimum Housing and Health Standards which states that: All heating facilities within a housing premises are to be properly installed and maintained in good working condition, and be capable of safely and adequately heating all habitable rooms, bathrooms, and toilet rooms within the building to a temperature of at least 22 degrees Celsius (71 degrees F), or maintained at a temperature of at least 22 degrees C(71 degrees F) when the control of the supplied heat in a dwelling is the responsibility of a person other than the occupant.
- e. The openable area in the bedroom window measured approximately 17 inches high and 14 inches wide, which is too small for emergency egress requirements. This is a contravention of section III(3)(b)(ii) of the Minimum Housing and Health Standards which states that: Windows referred to in section III(3)(b)(i) shall provide unobstructed openings with areas not less than 0.35 m² (3.8ft²), with no dimension less than 380 mm (15").
- f. There were electrical wires hanging from the kitchen ceiling. This is a contravention of section IV(11) of the Minimum Housing and Health Standards which states that: Every housing premises shall be supplied with electrical service. Outlets, switches and fixtures shall be properly installed and shall be maintained in a good and safe working condition.
- g. The smoke alarm installed was not operational. This is a contravention of section IV(12)(a) of the Minimum Housing and Health Standards which states that: Smoke alarms shall be operational and in good repair at all times.

AND WHEREAS, by virtue of the foregoing, the above noted premises are hereby declared to be **Unfit for Human Habitation**.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the occupants vacate the above noted premises on or before December 31, 2024.
2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Provide an approved plumbed in and consistent source of hot and cold potable running water to the suite.
 - b. Ensure the toilet operates properly and connect the suite to an approved sewage disposal system. Properly dispose of all human waste being stored in buckets at the site.
 - c. Ensure proper heating facilities are installed and can maintain the suite at a minimum temperature of 22 degrees Celsius.
 - d. Replace the bedroom window so it meets the requirements of section III3(b)(ii) of the Minimum Housing and Health Standards.
 - e. Install a fully operational smoke alarm near the bedroom.
3. That until such time as the work referred to above is completed to the satisfaction of an Executive Officer of Alberta Health Services; the above noted premises shall remain vacant and secure from unauthorized entry.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Calgary, Alberta, Dec 19, 2024.

Confirmation of a verbal order issued to Ankar Johal, Cindy Schofield, and Cheri Thomas on Dec 18, 2024.

Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186

Fax: 780-422-0914

Email: HealthAppealBoard@gov.ab.ca

Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Template revised October 13, 2022

Copy City of Calgary Safety Codes, Calgary Police Services

Calgary • Southport • Environmental Public Health

10101 Southport Road SW , Calgary, Alberta, Canada T2W 3N2

<https://www.ahs.ca/eph>