

## **ORDER OF AN EXECUTIVE OFFICER Boil Water Order**

**To:** Banff Trail Riders Ltd.  
1 Sundance Road  
Banff, AB  
“the Owner”

**And To:** Julie Canning  
“the Owner”

**RE:** The Drinking Water Supply located in Banff, Alberta and municipally described as: Banff Trail Riders - Stables , 1 Sundance Road.

**WHEREAS** I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted drinking water supply pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

**AND WHEREAS** such inspection disclosed that the following conditions exist in and about the above noted drinking water supply which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. The drinking water supply may be unsafe for human consumption as indicated by a water sample collected on October 30, 2017 that had a Total Coliform count of 8 per 100ml.
- b. The drinking water supply may be unsafe for human consumption as indicated by a water sample collected on November 2, 2017 that had a Total Coliform count of 1 per 100ml.

**AND WHEREAS** such inspection disclosed that the following breaches of the Public Health Act Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in and about the above noted Drinking Water Supply, namely:

- a. The drinking water supply may be unsafe for human consumption as indicated by a water sample collected on October 30, 2017 that had a Total Coliform count of 8 per 100ml which is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states “Where a person provides a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable.”
- b. The drinking water supply may be unsafe for human consumption as indicated by a water sample collected on November 2, 2017 that had a Total Coliform count of 1 per 100ml which is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states “Where a person provides a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable.”

AND WHEREAS by virtue of the foregoing, the above noted Drinking Water Supply is hereby declared **unfit for human consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately issues a Boil Water Advisory to all users of the above noted Drinking Water Supply.
2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted drinking water supply, namely:
  - a. Post boil water advisory in a location that is visible to all staff and public.
  - b. Provide bottled water or water that has been boiled for one minute for drinking until Alberta Health Services deems the water safe for human consumption.
  - c. Ensure potable water (bottled or boiled) is used for food preparation.
  - d. Provide hand sanitizer of at least 60% alcohol content at all hand wash sinks for disinfection of hands after they are washed.
  - e. Install a primary drinking water treatment system appropriate to the water source and acceptable to Environmental Public Health, or connect to an alternate approved water supply.
  - f. Prior to the installation of any water treatment system, plans must be submitted to Alberta Health Services – Environmental Public Health for review and approval.
3. The work referred to in **paragraph 2(a), 2(b), 2(c), and 2(d)** must be completed immediately. The work referred to in **paragraph 2(e) and 2(f)** shall be completed by June 30, 2017.
4. That, until such time as the work referred to in **paragraph 2** is completed to the satisfaction of the undersigned, or an executive officer of Alberta Health Services, that this order shall remain in effect.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Banff, Alberta, November 6, 2017.

Kori Woodard, CPHI(C)  
Executive Officer  
Alberta Health Services

You have the right to appeal

A person who      a) is directly affected by a decision of a Regional Health Authority, and  
                                 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board

c/o Central Reception  
Main Floor, Telus Plaza North Tower  
10025 Jasper Avenue NW  
Edmonton, Alberta, T5J 1S6  
Phone: 780-222-5186  
Fax: 780-422-0914  
Email: [HealthAppealBoard@gov.ab.ca](mailto:HealthAppealBoard@gov.ab.ca)  
Website: <http://www.health.alberta.ca/about/PHAB.html>

A Notice of Appeal form may be obtained by contacting Alberta Health Services at 780-342-0122 or by contacting the Public Health Appeal Board.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or [www.qp.gov.ab.ca](http://www.qp.gov.ab.ca).

Health Legislation and regulations are available for purchase. Please contact Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or [www.qp.gov.ab.ca](http://www.qp.gov.ab.ca).

Copies of standards are available by contacting the Health Protection Branch of Alberta Health at 780-427-4518 or by visiting: [www.health.alberta.ca/about/health-legislation.html](http://www.health.alberta.ca/about/health-legislation.html)

Template revised December 13, 2016

Copy: Planning Department, Town of Banff

---

**AIRDRIE Regional Health Centre**

604 Main Street South  
Airdrie, AB T4B 3K7  
Phone: 403-912-8400  
Fax: 403-912-8410

**BANFF Health Unit**

303 Lynx Street  
PO Box 1266  
Banff, AB T1L 1B3  
Phone: 403-762-2990  
Fax: 403-762-5570

**CALGARY - Southport Atrium**

10101 Southport Road SW  
Calgary, AB T2W 3N2  
Phone: 403-943-2288  
Fax: 403-943-8056

**CANMORE Public Health**

#104, 800 Railway Avenue  
Canmore, AB T1W 1P1  
Phone: 403-678-5656  
Fax: 403-678-5068

**CLARESHOLM Health Unit**

5221 2<sup>nd</sup> Street W  
PO Box 1391  
Claresholm, AB T0L 0T0  
Phone: 403 625-4061  
Fax: 403-625-4062

**COCHRANE Community Health Centre**

60 Grande Boulevard  
Cochrane, AB T4C 0S4  
Phone: 403-851-6000  
Fax: 403-851-6009

**OKOTOKS Health and Wellness Centre**

11 Cimarron Common  
Okotoks, AB T1S 2E9  
Phone: 403-995-2600  
Fax: 403-995-2639

**STRATHMORE Public Health Office**

650 Westchester Road  
Strathmore, AB T1P 1H8  
Phone: 403-361-7200  
Fax: 403-361-7244

[www.albertahealthservices.ca/eph.asp](http://www.albertahealthservices.ca/eph.asp)