

**ORDER OF AN EXECUTIVE OFFICER
CLOSED FOR TENANT ACCOMMODATION PURPOSES
ORDER TO VACATE**

To: Elizabeth Bell
"the Owner"

And To: All Occupant(s) of the following Housing premises: Basement, Unit 333 – 2211 19 Street NE

RE: Those housing premises located in Calgary, Alberta and municipally described as: Basement, Unit 333 – 2211 19 Street NE

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted premises pursuant to the provisions of the **Public Health Act**, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, in contravention of the *Public Health Act*, namely:

- a. The kitchen was set up near the hot water tank and furnace. Plumbing lines, ventilation, electrical wires, and concrete walls were exposed throughout the kitchen area.
- b. There was no window in the basement bedroom.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Housing Regulation, Alberta Regulation 173/99, and the Minimum Housing and Health Standards exist in and about the above noted premises, namely:

- a. The kitchen was set up near the hot water tank and furnace. Plumbing lines, ventilation, electrical wires, and concrete walls were exposed throughout the kitchen area. This is a contravention of section III(5)(b) which states that "Rooms and sections of rooms that are used for food preparation and cooking hall have walls and floors constructed of materials which do not provide harbourage to dirt, grease, vermin and bacteria and that are easily kept clean."
- b. There was no window in the basement bedroom. This is in contravention of section III(3)(b)(i) which states that "For buildings of 3 storeys or less and except where a bedroom door provides access directly to the exterior or the suite is sprinklered, each bedroom shall have at least one outside window which may be opened from the inside without the use of tools or special knowledge."

AND WHEREAS, by virtue of the foregoing, the above noted premises are hereby declared to be **Closed for Tenant Accommodation Purposes**.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner(s) takes all steps necessary to ensure all Occupants vacate the above noted premises on or before April 3, 2026
2. That the Owner(s) immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Ensure any area intended to be used for food preparation has appropriately finished walls, flooring, and ceiling. Consult with the City of Calgary for information to ensure that the space is compliant with relevant building codes.
 - b. Install a bedroom window so that it provides an unobstructed opening with an area not less than 0.35 m² (3.8ft²), with no dimension less than 380 mm (15")
3. That until such time as the work referred to above is completed to the satisfaction of an Executive Officer of Alberta Health Services; the above noted premises shall remain closed for tenant accommodation purposes.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Calgary, Alberta, March 4, 2026.

Confirmation of a verbal order issued to Elizabeth Bell on March 3, 2026.

Executive Officer
Environmental Health Officer

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Calgary • Southport • Environmental Public Health

10101 Southport Road SW, Calgary, Alberta, Canada, T2W 3N2

<https://www.ahs.ca/eph>