

ORDER OF AN EXECUTIVE OFFICER Boil Water Order

To: **Macey Brown**
"the Owner"

RE: The Drinking Water Supply located in Foothills County, Alberta and municipally described as:
Be.YOU.tiful Enhancements
482116 64 Street West Foothills County, Alberta

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted drinking water supply pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted drinking water supply which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. Water supplying the premise may be unsafe for human consumption as indicated by a water sample collected on January 10, 2025 showing the presence of Total Coliform bacteria per 100 mL.
- b. Water supplying the premise may be unsafe for human consumption as indicated by a water sample collected on January 13, 2025 showing the presence of 3 Total Coliform bacteria per 100 mL.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act Personal Services Regulation, Alberta Regulation 1/2020 exist in and about the above noted personal services establishment, namely:

- a. Water supplying the premise may be unsafe for human consumption as indicated by a water sample collected on January 10, 2025 showing the presence of Total Coliform bacteria per 100 mL which is in contravention of the Personal Services Regulation Section 5(1)(d) which states "A personal service facility must be supplied with water from a potable source."
- b. Water supplying the premise may be unsafe for human consumption as indicated by a water sample collected on January 13, 2025 showing the presence of 3 Total Coliform bacteria per 100 mL which is in contravention of the Personal Services Regulation Section 5(1)(d) which states "A personal service facility must be supplied with water from a potable source."

AND WHEREAS by virtue of the foregoing, the above noted Drinking Water Supply is hereby declared **Unfit for human consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately issues a Boil Water Advisory to all users of the above noted Drinking Water Supply.
2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted drinking water supply, namely:
 - a. Post do not drink advisory signs next to all water fixtures that are accessible to the public.
 - b. Provide potable water from an approved source or provide water that has been boiled for one minute to patrons or staff until the drinking water is deemed safe for human consumption by an Executive Officer of Alberta Health Services.
 - c. Provide hand sanitizer of at least 60 % alcohol content at all hand-washing sinks for the disinfection of hands after they are washed.
 - d. Use a safe alternative water source for all client procedures, treatments, instrument cleaning, washing broken skin, and for the preparation of any solutions.
 - e. Assess the water system to identify any potential causes of contamination and conduct any maintenance or treatment required,

OR

Install a water treatment system capable of treating groundwater through primary disinfection. Complete the required AHS submission forms for review and approval by an Executive Officer of Alberta Health Services prior to installation,

OR

Provide water from an alternate, approved source. Any proposal to change the source water must be submitted to AHS and approved prior to making modifications.

- f. Submit water samples, as directed by an Executive Officer, after completing the work described in 2(e) to demonstrate the water is potable.

3. The work referred to in paragraph 2 (a) – (d) shall be completed immediately.
4. The work referred to in paragraph 2 (e) to (f) shall be completed by February 28, 2025.
5. That, until such time as the work referred to in paragraph 2 is completed to the satisfaction of the undersigned, or an executive officer of Alberta Health Services, and the water samples submitted under paragraph (f) is shown to be satisfactory, that this order shall remain in effect.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Okotoks, Alberta, January 16, 2025

Confirmation of a verbal order issued to Macey Brown on January 16, 2025.

Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by contacting the Health Protection Branch of Alberta Health at 780-427-4518 or by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Template revised September 12, 2022

Calgary Zone • Southport Road • Environmental Public Health

10101 Southport Road, Calgary, Alberta, Canada T2E 3N2

www.albertahealthservices.ca/eph.asp