

ORDER OF AN EXECUTIVE OFFICER Boil Water Order

To: Fork Smart Inc.

"the Owner"

Zaina Randhawa "the Owner"

RE: The Drinking Water Supply located in Foothills County, Alberta and municipally described

as: Fork Smart, 246051 20 Street E

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have received a water sample report about the above noted drinking water supply pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such report disclosed that the following conditions exist in and about the above noted drinking water supply which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

a. Water supplying the premises may be unsafe for human consumption as indicated by a water sample collected on the 23rd of June 2025 that showed the presence of E.coli bacteria and Total Coliforms bacteria.

AND WHEREAS such report disclosed that the following breaches of the Public Health Act Food Regulation, Alberta Regulation 31/2006, exist in and about the above noted Drinking Water Supply, namely:

a. Water supplying the premises may be unsafe for human consumption as indicated by a water sample collected on the 23rd of June 2025 that showed the presence of E.coli bacteria and Total Coliform bacteria. This is in contravention of the Food Regulation Section 17(1)(f)(i), which states "An operator must ensure that, before operation of the commercial food establishment commences, the commercial food establishment is supplied with hot and cold running water that is safe for human consumption and available in quantities sufficient to meet the needs of the commercial food establishment".

AND WHEREAS by virtue of the foregoing, the above noted Drinking Water Supply is hereby declared **unfit for human consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately issues a Boil Water Advisory to all users of the above noted Drinking Water Supply.

- 2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted drinking water supply, namely:
 - a. Post do not drink advisory signs next to all water fixtures that are accessible to the public.
 - b. Provide hand sanitizer of at least 60% alcohol content at all handwashing sinks for the disinfection of hands after they are washed.
 - c. Provide potable water from an approved source or provide water that has been boiled for one minute to staff or patrons until the drinking water is deemed safe for human consumption by an Executive Officer of Alberta Health Services.
 - d. Ensure that all food processing and preparation is done with potable water from an approved source.
 - e. Discard ice and any other food or drink item made with untreated water which will be served uncooked.
 - f. Ensure that all utensils, counters, and food contact surfaces are sanitized using an approved sanitizing step.
 - g. Discontinue use of pop machines, ice machines, and any other equipment directly plumbed to water system.
 - h. Assess the water system to identify any potential causes of contamination and conduct any maintenance or treatment required.
 - i. If no clear source of correctable contamination can be identified: Install a water treatment system capable of treating groundwater through primary disinfection. Complete the required AHS submission forms for review and approval by an Executive Officer of Alberta Health Services prior to installation.

OR

- ii. Provide water from an alternate, approved source. Any proposal to change the source water must be submitted to AHS and approved prior to making modifications.
- i. Submit water samples as directed by an Executive Officer after completing the work described in 2(h) to demonstrate the water is potable.
- 3. The work referred to in paragraph 2 (a) through (g) shall be completed immediately.
- 4. The work referred to in paragraph 2 (h) and (i) shall be completed by the 23rd of July 2025.
- 5. That, until such time as the work referred to in paragraph 2 is completed to the satisfaction of the undersigned, or an executive officer of Alberta Health Services, and water samples

RE: The Drinking Water Supply located in Foothills County, Alberta and municipally described as: Fork Smart, 246051 20 Street E Page 3 of 3

submitted under paragraph 2(i) are shown to be satisfactory, this order shall remain in effect.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Okotoks, Alberta, on the 26th of June 2025.

Confirmation of a verbal order issued to Zaina Randhawa on the 25th of June 2025.

Executive Officer Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and

b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board c/o Central Reception Main Floor, ATB Place North Tower 10025 Jasper Avenue NW Edmonton, Alberta, T5J 1S6 Phone: 780-222-5186

Fax: 780-422-0914

Email: HealthAppealBoard@gov.ab.ca

Website: https://www.alberta.ca/public-health-appeal-board.aspx

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or https://www.alberta.ca/alberta-kings-printer.aspx.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or https://www.alberta.ca/alberta-kings-printer.aspx.

Copies of standards are available by contacting the Health Protection Branch of Alberta Health at 780-427-4518 or by visiting: https://www.alberta.ca/health-standards-and-guidelines.aspx