

ORDER OF AN EXECUTIVE OFFICER Boil Water Order

To: Daljit Bashin
"the Owner"

RE: The Drinking Water Supply located in High River, Alberta and municipally described as:
Grozone Greenhouse Brown House, 144019 466 Avenue E, High River, AB, T1V 1N3.

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have received a reports about the above noted drinking water supply pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such reports disclosed that the following conditions exist in and about the above noted drinking water supply which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. Water supplying the premises may be unsafe for human consumption as indicated by a water sample collected on September 16, 2026, that showed the presence of Total Coliforms bacteria per 100mL.
- b. Water supplying the premises may be unsafe for human consumption as indicated by a water sample collected on September 21, 2026, that showed the presence of 6 Total Coliforms bacteria per 100mL.

AND WHEREAS such reports disclosed that the following breaches of the Public Health Act Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in and about the above noted Drinking Water Supply, namely:

- a. Water supplying the premises may be unsafe for human consumption as indicated by a water sample collected on September 16, 2026, that showed the presence of Total Coliforms bacteria per 100mL which is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states "Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable".
- b. Water supplying the premises may be unsafe for human consumption as indicated by a water sample collected on September 21, 2026, that showed the presence of 6 Total Coliforms bacteria per 100mL which is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states "Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable".

AND WHEREAS by virtue of the foregoing, the above noted Drinking Water Supply is hereby declared **unfit for human consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately issues a Boil Water Advisory to all users of the above noted Drinking Water Supply.
2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted drinking water supply, namely:
 - a. Post do not drink advisory signs next to all water fixtures that are accessible to staff/tenants.
 - b. Provide hand sanitizer of at least 60% alcohol content at all handwashing sinks for the disinfection of hands after they are washed.
 - c. Provide potable water from an approved source or provide water that has been boiled for one minute to staff/tenants until the drinking water is deemed safe for human consumption by an Executive Officer of Alberta Health Services.
 - d. Assess the water system to identify any potential causes of contamination and conduct any maintenance required.
 - e. Submit additional water samples as directed by an Executive Officer once the work in 2(d) is complete.
3. The work referred to in paragraph 2 (a) through (c) must be completed immediately.
4. The work referred to in paragraph 2 (d) and (e) must be completed by October 25, 2026.
5. That, until such time as the work referred to in paragraph 2 is completed to the satisfaction of the undersigned, or an Executive Officer of Alberta Health Services, and water samples submitted under 2(e) are shown to be satisfactory this order shall remain in effect.

The above conditions were noted at the time of receipt of the reports and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at High River, Alberta, September 25, 2026

Confirmation of a verbal order issued to Daljit Bashin on September 25, 2026.

Executive Officer
Alberta Health Services

If you have any questions regarding the order, contact Environmental Public Health at 1-833-476-4743 or
<https://www.albertahealthservices.ca/eph/eph.aspx>

You have the right to appeal

A person who is directly affected by a decision may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower

10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Template revised June 2, 2026

Calgary • Southport • Environmental Public Health

10101 Southport Road SW, Calgary, Alberta, Canada T2W 3N2

<https://www.ahs.ca/eph>