

ORDER OF AN EXECUTIVE OFFICER NOTICE OF CLOSURE

To: Stanley Park Investments Ltd.
“the Owner”

RE: The “swimming pool” located in Calgary, Alberta and municipally described as:
Holiday Inn Express & Suites Macleod Trail South Calgary,
12025 Lake Fraser Drive SE

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. The bacteriological water sample collected from the swimming pool on February 13, 2026, had Total Coliforms present.
- b. The bacteriological water sample collected from the swimming pool on February 20, 2026, had Total Coliforms present.

AND WHEREAS such report disclosed that the following breaches of the Public Health Act and the Public Swimming Pools Regulation, Alberta Regulation 204/2014 and the Pool Standards there under exist in and about the above noted premises, namely:

- a. The bacteriological water sample collected from the swimming pool on February 13, 2026, had Total Coliforms present. This is in contravention of 6.1 of the Pool Standards, July 2014 (Amended January 2018) which states: The quality of water in a public swimming pool must be maintained so that the water: (a) does not have a heterotrophic plate count greater than 100 colony forming units per milliliter in a 100-milliliter sample, or (b) show the presence of total coliform in a 100 milliliter sample.
- b. The bacteriological water sample collected from the swimming pool on February 20, 2026, had Total Coliforms present. This is in contravention of 6.1 of the Pool Standards, July 2014 (Amended January 2018) which states: The quality of water in a public swimming pool must be maintained so that the water: (a) does not have a heterotrophic plate count greater than 100 colony forming units per milliliter in a 100-milliliter sample, or (b) show the presence of total coliform in a 100 milliliter sample.

AND WHEREAS, by virtue of the foregoing, the above noted premises are hereby declared to be **Closed**.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately close the above noted premises.
2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Submit a water sample from the swimming pool which yields a satisfactory result.
3. That until such time as the work referred to above is completed to the satisfaction of an Executive Officer of Alberta Health Services; the above noted premises shall remain closed.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Calgary, Alberta, February, 23, 2026.

Confirmation of a verbal order issued to Rayla Derenowski, Hotel General Manager, on February 23, 2026.

Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Calgary • Southport • Environmental Public Health

10101 Southport Road SW Calgary, AB Canada T2W 3N2

<https://www.ahs.ca/eph>