

## **ORDER OF AN EXECUTIVE OFFICER Boil Water Order**

**To:** Bottrel Busy Beavers  
"the Owner"

Kim Krebs  
"the Owner"

**RE:** The Drinking Water Supply located in Mountain View County, Alberta and municipally described as: Old Dogpound Stampede Hall, 4242 Township Road 290

**WHEREAS** I, an **Executive Officer of Alberta Health Services**, have inspected the above noted drinking water supply pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

**AND WHEREAS** such inspection disclosed that the following conditions exist in and about the above noted drinking water supply which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. AHS has determined the water well supplying this facility to be a vulnerable water source requiring primary water treatment. The previously installed water treatment system has been modified in a manner that does not meet primary water treatment standards.

**AND WHEREAS** such inspection disclosed that the following breaches of the Public Health Act Food Regulation, Alberta Regulation 31/2006 exist in and about the above noted Drinking Water Supply, namely:

- a. AHS has determined the water well supplying this facility to be a vulnerable water source requiring primary water treatment. The previously installed water treatment system has been modified in a manner that does not meet primary water treatment standards. This is in contravention of Food Regulation Section 17(1)(f)(i), which states "An operator must ensure that, before operation of the commercial food establishment commences, the commercial food establishment is supplied with hot and cold running water that is safe for human consumption and available in quantities sufficient to meet the needs of the commercial food establishment".

**AND WHEREAS** by virtue of the foregoing, the above noted Drinking Water Supply is hereby declared **unfit for human consumption**;

**NOW THEREFORE**, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately issues a Boil Water Advisory to all users of the above noted Drinking Water Supply.
2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted drinking water supply, namely:

- a. Post do not drink advisory signs next to all accessible water fixtures.
  - b. Provide hand sanitizer of at least 60% alcohol content at all handwashing sinks for the disinfection of hands after they are washed.
  - c. Provide potable water from an approved source or provide water that has been boiled for one minute to facility users until the drinking water is deemed safe for human consumption by an Executive Officer of Alberta Health Services.
  - d. Ensure that all food processing and preparation is done with potable water from an approved source.
  - e. Ensure that all utensils, counters, and food contact surfaces are sanitized using an approved sanitizing step.
  - f. Complete at least one of the following:
    - i. Modify the current water treatment system to meet primary disinfection standards outlined in the AHS document “Public Health Guidelines for Non-municipal Drinking Water”. Provide plans for any modifications to AHS and obtain approval from an Executive Officer prior to performing any additional work.
    - ii. Address the previously noted well vulnerabilities by installing a pit-less well adaptor to remove the pit well and submit bacteriological water samples at the direction of an Executive Officer of AHS to establish a routine sampling baseline.
    - iii. Use an approved alternative potable water source to supply the kitchen and washrooms of this facility.
3. The work referred to in paragraph 2(a-e) shall be completed immediately.
  4. The work referred to in paragraph 2(f) shall be completed on or before the 1<sup>st</sup> of June 2026.
  5. That, until such time as the work referred to in paragraph 2 is completed to the satisfaction of the undersigned, or an executive officer of Alberta Health Services, that this order shall remain in effect.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Calgary, Alberta, on the 27<sup>th</sup> of August 2025.

Executive Officer  
Alberta Health Services

You have the right to appeal

A person who      a) is directly affected by a decision of a Regional Health Authority, and  
                             b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board  
c/o Central Reception  
Main Floor, ATB Place North Tower  
10025 Jasper Avenue NW  
Edmonton, Alberta, T5J 1S6  
Phone: 780-222-5186  
Fax: 780-422-0914  
Email: [HealthAppealBoard@gov.ab.ca](mailto:HealthAppealBoard@gov.ab.ca)  
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

**Copies of standards are available by contacting the Health Protection Branch of Alberta Health at 780-427-4518 or by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>**

Template revised April 17, 2025

---

Calgary • Southport • Environmental Public Health

10101 Southport Road, Calgary, Alberta, Canada T2E 3N2

[www.ahs.ca/eph](http://www.ahs.ca/eph)

PSD-0315-202205