

ORDER OF AN EXECUTIVE OFFICER Boil Water Order

To: Peter Huyzer
"the Owner"

RE: The Drinking Water Supply located in the Hamlet of Cluny, Alberta and municipally described as:

Pete's Bakery
236 1st Avenue
Cluny, Alberta

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted drinking water supply pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted drinking water supply which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. Water supplying the premise may be unsafe for human consumption as indicated by a water sample collected on May 8, 2018 showed the presence of Total Coliform bacteria.
- b. Water supplying the premise may be unsafe for human consumption as indicated by a water sample collected on May 11, 2018 showed the presence of 1 Total Coliform bacteria per 100ml.
- c. Water supplying the premise may be unsafe for human consumption as indicated by a water sample collected on May 14, 2018 showed the presence of 1 Total Coliform bacteria per 100ml.
- d. Water supplying the premise may be unsafe for human consumption as indicated by a water sample collected on May 15, 2018 showed the presence of 2 Total Coliform bacteria per 100ml.

AND WHEREAS such inspection disclosed that the following breaches of the such inspection disclosed that the following breaches of the Public Health Act Food Regulation, Alberta Regulation 31/2006 and the Food Retail and Foodservices Code exist in and about the above noted food establishment, namely:

- a. Water supplying the premise may be unsafe for human consumption as indicated by a water sample collected on May 8, 2018 showed the presence of Total Coliform bacteria, which is in contravention of the Food Regulation Section 17(1)(f)(i) which states "an operator must ensure that, before operation of the commercial food establishment commences, the commercial food establishment is supplied with hot and cold running water that is safe for human consumption and available in quantities sufficient to meet the needs of the commercial establishment.

- b. Water supplying the premise may be unsafe for human consumption as indicated by a water sample collected on May 11, 2018 showed the presence of 1 Total Coliform bacteria per 100ml, which is in contravention of the Food Regulation Section 17(1)(f)(i) which states “an operator must ensure that, before operation of the commercial food establishment commences, the commercial food establishment is supplied with hot and cold running water that is safe for human consumption and available in quantities sufficient to meet the needs of the commercial establishment.
- c. Water supplying the premise may be unsafe for human consumption as indicated by a water sample collected on May 14, 2018 showed the presence of 1 Total Coliform bacteria per 100ml, which is in contravention of the Food Regulation Section 17(1)(f)(i) which states “an operator must ensure that, before operation of the commercial food establishment commences, the commercial food establishment is supplied with hot and cold running water that is safe for human consumption and available in quantities sufficient to meet the needs of the commercial establishment.
- d. Water supplying the premise may be unsafe for human consumption as indicated by a water sample collected on May 15, 2018 showed the presence of 2 Total Coliform bacteria per 100ml, which is in contravention of the Food Regulation Section 17(1)(f)(i) which states “an operator must ensure that, before operation of the commercial food establishment commences, the commercial food establishment is supplied with hot and cold running water that is safe for human consumption and available in quantities sufficient to meet the needs of the commercial establishment.

AND WHEREAS by virtue of the foregoing, the above noted Drinking Water Supply is hereby declared **unfit for human consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

- 1. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted drinking water supply, namely:
 - a. Post do not drink advisory signs next to all water fixtures that are accessible to the public.
 - b. Provide hand sanitizer of at least 60% alcohol content at all hand-washing sinks for the disinfection of hands after they are washed.
 - c. Ensure that all food processing and preparation is done with potable water from an approved source or with water that has been boiled for one minute.
 - d. Ensure that all utensils, counters, and food contact surfaces are sanitized using an approved sanitizing step.
 - e. Ensure that after hand washing, food handlers are disinfecting hands with an alcohol based hand sanitizer of at least 60% alcohol content.

- f. Install water treatment capable of treating groundwater under the direct influence of surface water. Any such treatment system must be approved by AHS prior to it's installation.
 - or
 - Install a CSA approved cistern of adequate size and haul potable water
 - or
 - Connect to another potable water supply.
- 2. The work referred to in paragraph 1 (a) – (e) shall be completed immediately.
- 3. The work referred to in paragraph 1 (f) shall be completed by June 29, 2018.
- 4. That, until such time as the work referred to in **paragraph 1 - 3** is completed to the satisfaction of the undersigned, or an executive officer of Alberta Health Services, that this order shall remain in effect.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Strathmore, Alberta, May 17, 2018.

Confirmation of a verbal order issued to Peter Huyzer on May 14, 2018.

Norman Kruesel, CPHI(C)
Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, Telus Plaza North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <http://www.health.alberta.ca/about/PHAB.html>

A Notice of Appeal form may be obtained by contacting Alberta Health Services at 780-342-0122 or by contacting the Public Health Appeal Board.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or www.qp.gov.ab.ca.

Health Legislation and regulations are available for purchase. Please contact Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or www.qp.gov.ab.ca.

Copies of standards are available by contacting the Health Protection Branch of Alberta Health at 780-427-4518 or by visiting: www.health.alberta.ca/about/health-legislation.html

AIRDRIE Regional Health Centre

604 Main Street South
Airdrie, AB T4B 3K7
Phone: 403-912-8400
Fax: 403-912-8410

BANFF Health Unit

303 Lynx Street
PO Box 1266
Banff, AB T1L 1B3
Phone: 403-762-2990
Fax: 403-762-5570

CALGARY - Southport Atrium

10101 Southport Road SW
Calgary, AB T2W 3N2
Phone: 403-943-2288
Fax: 403-943-8056

CANMORE Public Health

#104, 800 Railway Avenue
Canmore, AB T1W 1P1
Phone: 403-678-5656
Fax: 403-678-5068

CLARESHOLM Health Unit

5221 2nd Street W
PO Box 1391
Claresholm, AB T0L 0T0
Phone: 403 625-4061
Fax: 403-625-4062

COCHRANE Community Health Centre

60 Grande Boulevard
Cochrane, AB T4C 0S4
Phone: 403-851-6000
Fax: 403- 851-6009

OKOTOKS Health and Wellness Centre

11 Cimarron Common
Okotoks, AB T1S 2E9
Phone: 403-995-2600
Fax: 403-995-2639

STRATHMORE Public Health Office

650 Westchester Road
Strathmore, AB T1P 1H8
Phone: 403-361-7200
Fax: 403-361-7244

www.albertahealthservices.ca/eph.asp