

ORDER OF AN EXECUTIVE OFFICER Boil Water Order

To: Peter Huyzer
"the Owner"

Katherine Huyzer
"the Owner"

RE: The Drinking Water Supply located in Cuny, Alberta and municipally described as:

Pete's Bakery
236 1 Avenue
Cluny, Alberta

WHEREAS I, an **Executive Officer of Alberta Health Services**, have inspected the above noted drinking water supply pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted drinking water supply which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. A bacteriological water sample collected on March 17, 2026 showed the presence Total Coliforms.
- b. The ultraviolet light treatment device was malfunctioning, displaying an error code.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in and about the above noted Drinking Water Supply, namely:

- a. A bacteriological water sample collected on March 17, 2026 showed the presence Total Coliforms which is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states "Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable".
- b. The ultraviolet light treatment device was malfunctioning, displaying an error code which is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states "Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable".

AND WHEREAS by virtue of the foregoing, the above noted Drinking Water Supply is hereby declared **unfit for human consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted drinking water supply, namely:
 - a. Post do not drink advisory signs next to all water fixtures that are accessible to the public.
 - b. Provide hand sanitizer of at least 60% alcohol content at all hand-washing sinks for the disinfection of hands after they are washed.
 - c. Ensure that all food processing and preparation is done with potable water from an approved source or with water that has been boiled for one minute.
 - d. Ensure that all utensils, counters, and food contact surfaces are sanitized using an approved sanitizing step.
 - e. Ensure that after hand washing, food handlers are disinfecting hands with an alcohol based hand sanitizer of at least 60% alcohol content.
 - f. Conduct any necessary maintenance work on the drinking water system to render the water potable.
2. The work referred to in paragraph 1 (a) – (e) shall be completed immediately.
3. The work referred to in paragraph 1 (f) shall be completed by May 1, 2026.
4. That, until such time as the work referred to in paragraph 1 is completed to the satisfaction of the undersigned, or an executive officer of Alberta Health Services, that this order shall remain in effect.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Strathmore, Alberta, March 23, 2026.

Confirmation of a verbal order issued to Katherine Huyzer on March 20, 2026.

Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower

10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by contacting the Health Protection Branch of Alberta Health at 780-427-4518 or by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Strathmore • Strathmore Public Health Unit • Environmental Public Health

650 Westchester Road, Strathmore, Alberta, Canada T1P 1B2

<https://www.ahs.ca/eph>