

ORDER OF AN EXECUTIVE OFFICER NOTICE OF CLOSURE

To: Platinum Hospitality Inc.
“the Owner”

Rajdeep Sohi
“the Owner”

Inderjeet Sumal
“the Owner”

Rajvinder Uppal
“the Owner”

Anil Yadav
“the Owner”

RE: The “pool” located in Calgary, Alberta and municipally described as:
Radisson Hotel Calgary Airport – Whirlpool
6620 36 Street NE

WHEREAS I, an **Executive Officer of Alberta Health Services**, have received a report about the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such report disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. The water sample collected on March 20, 2026, tested positive for *Pseudomonas aeruginosa*.
- b. The water sample collected on March 25, 2026, tested positive for *Pseudomonas aeruginosa*.
- c. The water sample collected on March 25, 2026, tested positive for Total Coliforms.
- d. The water sample collected on March 25, 2026, had a Heterotrophic Plate Count of >57,000 CFU/mL.

AND WHEREAS such report disclosed that the following breaches of the Public Health Act and the Public Swimming Pools Regulation, Alberta Regulation 204/2014 and the Pool Standards there under exist in and about the above noted premises, namely:

- a. The water sample collected on March 20, 2026, tested positive for *Pseudomonas aeruginosa*. This is in contravention of the Pool Standards, July 2014 (Amended January 2018), section 6.2, which states: In addition to 6.1, the quality of water in a public swimming

pool operating at greater than 30 degrees Celsius must be maintained so that samples of the water do not show the presence of *Pseudomonas aeruginosa*.

- b. The water sample collected on March 25, 2026, tested positive for *Pseudomonas aeruginosa*. This is in contravention of the Pool Standards, July 2014 (Amended January 2018), section 6.2, which states: In addition to 6.1, the quality of water in a public swimming pool operating at greater than 30 degrees Celsius must be maintained so that samples of the water do not show the presence of *Pseudomonas aeruginosa*.
- c. The water sample collected on March 25, 2026, tested positive for Total Coliforms. This is in contravention of the Pool Standards, July 2014 (Amended January 2018), section 6.1(b), which states: The quality of water in a public swimming pool must be maintained so that the water does not show the presence of total coliforms in a 100-milliliter sample.
- d. The water sample collected on March 25, 2026, had a Heterotrophic Plate Count of >57,000 CFU/mL. This is in contravention of the Pool Standards, July 2014 (Amended January 2018), section 6.1(a), which states: The quality of water in a public swimming pool must be maintained so that the water does not have a heterotrophic plate count greater than 100 colony forming units per milliliter in a 100-milliliter sample.

AND WHEREAS, by virtue of the foregoing, the above noted premises are hereby declared to be **Closed**.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately close the above noted premises.
2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Backwash the whirlpool.
 - b. Treat the whirlpool by following either of these treatments:
 - i. Increase Free Available Chlorine (FAC) level to 20 - 50 ppm (with non-stabilized chlorine) and maintain a pH of 7.5 or lower, or
 - ii. Increase the FAC to 10 ppm and lower the pH to 6.8 - 7.0, or
 - iii. Use a commercial treatment that utilizes an alternative disinfectant/oxidizer (accelerated hydrogen peroxide or chlorine dioxide).
Follow the manufacturer's instructions.
 - c. Run the water through the circulation system for at least 4 - 6 hours.
 - d. Completely drain the whirlpool.
 - e. Scrub the whirlpool pool surfaces with acid or sanitizer.
 - f. Rinse off acid/sanitizer.
 - g. Refill the pool.
 - h. Adjust water chemistry to regular operating parameters.
 - i. Take a water sample and send it to the Prov lab.
3. That until such time as the work referred to above is completed to the satisfaction of an Executive Officer of Alberta Health Services; and the water sample in paragraph 2(i) is satisfactory, the above noted premises shall remain closed.

The above conditions were noted at the time of receipt of the report and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Calgary, Alberta, March 30, 2026.

Confirmation of a verbal order issued to Anil Yadav on March 27, 2026.

Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Template revised April 17, 2025

Copy: City of Calgary

Order of an Executive Officer – Notice of Closure

RE: The Pool located in Calgary, Alberta and municipally described as: Radisson Hotel Calgary Airport – Whirlpool
6620 36 Street NE

Page 4 of 4

Calgary • Southport • Environmental Public Health

10101 Southport Road SW, Calgary, Alberta, Canada T2W 3N2

<https://www.ahs.ca/eph>