

**ORDER OF AN EXECUTIVE OFFICER  
CLOSED FOR TENANT ACCOMMODATION PURPOSES  
ORDER TO VACATE**

**To:** 310117 Alberta Ltd.  
"the Owner"  
Regina Donnelly  
"the Director"

The Realty Store  
"the Property Manager"

**And To:** All Occupant(s) of the following Housing premises:

**RE:** Those housing premises located in Red Deer, Alberta and municipally described as:  
4614 50 Street – Basement

**WHEREAS** I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted premises pursuant to the provisions of the **Public Health Act**, RSA 2000, c. P-37, as amended;

**AND WHEREAS** such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, in contravention of the Public Health Act and Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 namely:

- a. The windows located in the southeast bedroom measure approximately 10 inches by 11 inches and cannot be opened for emergency egress.
- b. There is no smoke alarm installed in the hallway serving the southeast bedroom.

**AND WHEREAS** such inspection disclosed that the following breaches of the Public Health Act and the Housing Regulation, Alberta Regulation 173/99, and the Minimum Housing and Health Standards exist in and about the above noted premises, namely:

- a. The windows located in the southeast bedroom measure approximately 10 inches by 11 inches and cannot be opened for emergency egress. This is in contravention of section 3(b)(ii) of the Minimum Housing and Health Standards which states: "Windows referred to in section 3(b)(i) shall provide unobstructed openings with areas not less than 0.35 m<sup>2</sup> (3.8ft<sup>2</sup>), with no dimension less than 380 mm (15")."
- b. There is no smoke alarm installed in the hallway serving the southeast bedroom. This is in contravention of section 12 of the Minimum Housing and Health Standards which states: "Smoke alarms within dwellings shall be installed between each sleeping area and the remainder of the suite and, where hallways serve the sleeping areas; the smoke alarms shall be installed within the hallway. "

**AND WHEREAS**, by virtue of the foregoing, the above noted premises are hereby declared to be **Closed for Tenant Accommodation Purposes**.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner(s) takes all steps necessary to ensure all Occupants vacate the above noted premises on November 13, 2025.
2. That the Owner(s) immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
  - a. Ensure that the southeast bedroom complies with the emergency egress requirements as outlined in the Minimum Housing and Health Standards.
  - b. Install an operational smoke alarm in the hallway serving the bedroom.
3. That until such time as the work referred to above is completed to the satisfaction of an Executive Officer of Alberta Health Services; the above noted premises shall remain closed for tenant accommodation purposes.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Red Deer, Alberta, November 14, 2025.

Confirmation of a verbal order issued to Sarina Nepoose on November 13, 2025.

(Original Signed)

Executive Officer  
Environmental Health Officer

You have the right to appeal

A person who      a) is directly affected by a decision of a Regional Health Authority, and  
                             b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board  
c/o Central Reception  
Main Floor, ATB Place North Tower  
10025 Jasper Avenue NW  
Edmonton, Alberta, T5J 1S6  
Phone: 780-222-5186  
Fax: 780-422-0914  
Email: [HealthAppealBoard@gov.ab.ca](mailto:HealthAppealBoard@gov.ab.ca)  
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

**Copies of standards are available by visiting:** <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Template revised September 17, 2025

---

Red Deer • Johnstone Crossing Community Health Centre • Environmental Public Health

300 Jordan Parkway, Red Deer, AB, Canada T4P 0G8

<https://www.ahs.ca/eph>