

ORDER OF AN EXECUTIVE OFFICER NOTICE OF CLOSURE

To: 1949561 Alberta Ltd.
William MacLean
Carla MacLean
“the Owners”

RE: The “pool” located in Eckville, Alberta and municipally described as:
Alberta Views Golf & RV Resort – Pool, 39325 Range Road 34.

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have received a report about the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such report disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. No pool water samples have been submitted to verify the water quality of the pool for the 2026 operating season.

AND WHEREAS such report disclosed that the following breaches of the Public Health Act and the Public Swimming Pools Regulation, Alberta Regulation 204/2014 and the Pool Standards there under exist in and about the above noted premises, namely:

- a. No pool water samples have been submitted to verify the water quality of the pool for the 2026 operating season. This is in contravention of Section 19(1)(a) of the Public Swimming Pools Regulation which states, “A sample of the water in a public swimming pool must be taken and submitted to the Provincial Laboratory of Public Health for microbiological testing in accordance with the Pool Standards every week.”

AND WHEREAS, by virtue of the foregoing, the above noted premises are hereby declared to be **Closed**.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately close the above noted premises.
2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Ensure water samples are submitted in accordance with the Pool Standards.
 - b. Submit a satisfactory sample of water taken from the pool to the Provincial Laboratory of Public Health.

3. That until such time as the work referred to above is completed to the satisfaction of an Executive Officer of Alberta Health Services; the above noted premises shall remain closed.

The above conditions were noted at the time of receipt of the report and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Sylvan Lake, Alberta, July 22, 2026.

Confirmation of a verbal order issued to William MacLean on July 22, 2026.

Executive Officer
Alberta Health Services

If you have any questions regarding the order, contact Environmental Public Health at 1-833-476-4743 or <https://www.albertahealthservices.ca/eph/eph.aspx>

You have the right to appeal

A person who is directly affected by a decision may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Template revised June 2, 2026