

ORDER OF AN EXECUTIVE OFFICER Boil Water Order

To: 475186 Alberta Inc.
Gail Williamson
"the Owners"

RE: The Drinking Water Supply located in Clearwater County, Alberta and municipally described as: Boundary RV Park – Campground, 894038 Highway 591

WHEREAS I, an **Executive Officer of Alberta Health Services**, have received reports about the above noted drinking water supply pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection and reports disclosed that the following conditions exist in and about the above noted drinking water supply which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. Ongoing intermittent bacteriological water sample results with the presence of total coliform bacteria.
- b. The system does not provide means for continuous disinfection to inactivate pathogenic microorganisms (e.g., viruses, bacteria, protozoa).
- c. The well is deemed vulnerable to contamination.

AND WHEREAS such inspection and reports disclosed that the following breaches of the Public Health Act Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 and the Recreation Area Regulation, Alberta Regulation 198/2004 exist in and about the above noted Drinking Water Supply, namely:

- a. Ongoing intermittent bacteriological water sample results with the presence of total coliform bacteria which is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states "Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable." and Section 7(1) of the Recreation Area Regulation (198/2004), which states "If a recreation area supplies water for human consumption, to a sink or shower facility, or through hook up to a recreational vehicle, the water must be potable."

AND WHEREAS by virtue of the foregoing, the above noted Drinking Water Supply is hereby declared **unfit for human consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately issues a Boil Water Advisory to all users of the above noted Drinking Water Supply by:

- a. Advise all affected users of the water supply that water used for drinking, making infant formula and juices, cooking, making ice, washing fruits and vegetables, brushing teeth, must be boiled for at least 1 minute prior to use.
 - b. Post clear signage at all locations where water from the aforementioned supply is accessible to the public, advising users that the water is not safe for consumption. Additionally, ensure that hand sanitizer containing 60% to 90% alcohol is provided at all handwashing stations.
2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted drinking water supply, namely:
 - a. Provide a map of the distribution system that identifies the components and connections to determine extent of service and to identify representative sample locations.
 - b. Design and install a primary disinfection system capable of meeting the required log reductions of pathogens as per Section 6.1.2 Vulnerable Groundwater of the Public Health Guidelines for Non-Municipal Drinking Water (July 2021).
 - c. Provide 2 sets of satisfactory bacteriological results from at least 2 other locations within the distribution system as approved by an executive officer.
3. The work referred to in paragraph 2 shall be completed prior to opening for the operational season on May 15, 2026.
4. That, until such time as the work referred to in paragraph 2 is completed to the satisfaction of the undersigned, or an executive officer of Alberta Health Services, that this order shall remain in effect.

The above conditions were noted at the time of receipt of the reports and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Rocky Mountain House, Alberta, October 3, 2025.

Confirmation of a verbal order issued to Gail Williamson on October 3, 2025.

Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board

c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by contacting the Health Protection Branch of Alberta Health at 780-427-4518 or by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Template revised April 17, 2025