

ORDER OF AN EXECUTIVE OFFICER NOTICE OF CLOSURE

To: Camp Caroline Society
"the Owner"

RE: The "pool" located in Clearwater County, Alberta and municipally described as:
Camp Caroline – Whirlpool, 354040 Range Road 6-1

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have received a report about the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such report disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. The water sample taken on Wednesday January 28, 2026, had *Pseudomonas aeruginosa* isolated.
- b. The water sample taken on Wednesday January 28, 2026, had a Heterotrophic Plate Count of >57,000 colony forming units per milliliter.

AND WHEREAS such report disclosed that the following breaches of the Public Health Act and the Public Swimming Pools Regulation, Alberta Regulation 204/2014 and the Pool Standards there under exist in and about the above noted premises, namely:

- a. The water sample taken on Wednesday January 28, 2026, had *Pseudomonas aeruginosa* isolated. This is in contravention of Section 6.2 of the Alberta Swimming Pool Standards July 2014 (Amended January 2018), which states that, "in addition to 6.1, the quality of water in a public swimming pool operating at greater than 30 degrees Celsius must be maintained so that samples of the water do not show the presence of *Pseudomonas aeruginosa*."
- b. The water sample taken on Wednesday January 28, 2026, had a Heterotrophic Plate Count of >57,000 colony forming units per milliliter. This is in contravention of Section 6.1(a) of the Alberta Swimming Pool Standards July 2014 (Amended January 2018), which states that, "The quality of water in a public swimming pool must be maintained so that the water does not: have a heterotrophic plate count greater than 100 colony forming units per milliliter in a 100-milliliter sample."

AND WHEREAS, by virtue of the foregoing, the above noted premises are hereby declared to be **Closed**.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately close the above noted premises.

2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Treat the whirlpool water to eliminate any possible source of contamination, drain, refill, and then chemically balance the whirlpool water.
 - b. Submit a bacteriological water sample of the whirlpool water to the Provincial Laboratory and that is returned with satisfactory results.

3. That until such time as the work referred to above is completed to the satisfaction of an Executive Officer of Alberta Health Services; the above noted premises shall remain closed.

The above conditions were noted at the time of receipt of the report and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Rocky Mountain House, Alberta, February 2, 2026

Confirmation of a verbal order issued to Vern Enslin on February 2, 2026.

Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Template revised April 17, 2025