

ORDER OF AN EXECUTIVE OFFICER

To: Cellar Door Farm Ltd.
Jennifer Belbeck
"the Owners"

RE: The food establishment located in Beaver County, Alberta and municipally described as:
Cellar Door Farm, 50006 Range Road 190

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have received a report about the above noted premises pursuant to the provisions of the **Public Health Act**, RSA 2000, c. P-37, as amended;

AND WHEREAS such report disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. The drinking water supply serving Cellar Door Farm may be unsafe for human consumption as indicated by the presence of Total Coliforms and E. coli for the sample collected on July 7, 2026.

AND WHEREAS such report disclosed that the following breaches of the Public Health Act and the Food Regulation, Alberta Regulation 31/2006 and the Food Retail and Foodservices Code, and the Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in and about the above noted premises, namely:

- a. The drinking water supply serving Cellar Door Farm may be unsafe for human consumption as indicated by the presence of Total Coliforms and E. coli and which is in contravention of the Nuisance and General Sanitation Regulation Section 11 which states "Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable."

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Use boiled water, bottled water, or water from another safe public water source for any food preparation.
 - b. Shock chlorinate the water well system and flush all lines.
 - c. Submit two consecutive bacteriological water samples, collected not less than 24 hours apart that do not show the presence of Total Coliforms and E. coli.
2. The work referred to in paragraph 1 shall be completed by July 24, 2026.

The above conditions were noted at the time of receipt of the report and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Tofield, Alberta, July 14, 2026.

Confirmation of a verbal order issued to Jennifer Belbeck on July 14, 2026.

Executive Officer
Alberta Health Services

If you have any questions regarding the order, contact Environmental Public Health at 1-833-476-4743 or
<https://www.albertahealthservices.ca/eph/eph.aspx>

You have the right to appeal

A person who is directly affected by a decision may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or
<https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Template revised June 2, 2026

Copy: Beaver County