

## **ORDER OF AN EXECUTIVE OFFICER NOTICE OF CLOSURE**

**To:** Dimension 3 Hospitality Corp.  
“the Owner”

**RE:** The “swimming pool” located in Red Deer, Alberta and municipally described as:  
Days Inn by Wyndham Red Deer - Pool, #1000 5001 19 Street

**WHEREAS** I, an **Executive Officer of Alberta Health Services**, have inspected the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

**AND WHEREAS** such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. The previous three consecutive bacteriological water samples (collected on May 8, May 15 and May 22, 2024) are unsatisfactory. Specifically, the water sample collected on May 8, 2024, had a heterotrophic plate count of >57,000 CFU/mL. The water sample collected on May 15, 2024, had a heterotrophic plate count of >2189 CFU/mL and the water sample collected on May 22, 2024, had total coliforms present.

**AND WHEREAS** such inspection disclosed that the following breaches of the Public Health Act and the Public Swimming Pools Regulation, Alberta Regulation 204/2014 and the Pool Standards there under exist in and about the above noted premises, namely:

- a. The previous three consecutive bacteriological water samples (collected on May 8, May 15 and May 22, 2024) are unsatisfactory. Specifically, the water sample collected on May 8, 2024, had a heterotrophic plate count of >57,000 CFU/mL. The water sample collected on May 15, 2024, had a heterotrophic plate count of >2189 CFU/mL and the water sample collected on May 22, 2024, had total coliforms present. This is in contravention of Section 6.1(a) and 6.1(b) of the Pool Standards, which states: “The quality of water in a swimming pool must be maintained so that the water does not have a heterotrophic plate count greater than 100 colony forming units per millilitre in a 100 millilitre sample or show the presence of total coliforms in a 100 millilitre sample.”

**AND WHEREAS**, by virtue of the foregoing, the above noted premises are hereby declared to be **Closed**.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately close the above noted premises.
2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:

- a. Treat the swimming pool to eliminate any possible sources of contamination.
  - b. Chemically balance the swimming pool water.
  - c. Collect and submit a bacteriological water sample from the swimming pool to the Provincial Laboratory, as a satisfactory water sample is required prior to re-opening the swimming pool.
3. That until such time as the work referred to above is completed to the satisfaction of an Executive Officer of Alberta Health Services; the above noted premises shall remain closed.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Red Deer, Alberta, May 27, 2024

Confirmation of a verbal order issued to Pool Operator, Avery Donald, on May 27, 2024.

Executive Officer  
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and  
b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board  
c/o Central Reception  
Main Floor, ATB Place North Tower  
10025 Jasper Avenue NW  
Edmonton, Alberta, T5J 1S6  
Phone: 780-222-5186  
Fax: 780-422-0914  
Email: [HealthAppealBoard@gov.ab.ca](mailto:HealthAppealBoard@gov.ab.ca)  
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

**Copies of standards are available by visiting:** <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Template revised October 13, 2022