

ORDER OF AN EXECUTIVE OFFICER

To: Summerhill Resorts Ltd.
"the Owner"

Dagmar Hargreaves
Manager

RE: Those premises located in Red Deer County, Alberta and municipally described as:
Dickson RV Resort Drinking Water System, 35342 Range Road 25

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. The water supply that services the recreational vehicle sites is not potable as there have been multiple unsatisfactory water results that do not confirm to the minimum potability requirements of the Canadian Drinking Water Guidelines.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Recreation Area Regulation Alberta Regulation 198/2004 exist in and about the above noted premises, namely:

- a. The water supply that services the recreational vehicle sites is not potable. This is in contravention of the Recreation Area Regulation section 7(1)(c) which states, "If a recreation area supplies water through hook up to a recreational vehicle, the water must be potable. And, section 7(2)(b) which states, "Where a recreation area supplies potable water, the potable water supply must be kept in a clean and sanitary state."

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. The Boil Water Order is to remain in effect for the resort until all conditions of this order have been met and approved by the Executive Officer.
2. The work referred to in paragraph 1 shall be completed by April 30, 2024.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Olds, Alberta July 13, 2023

Confirmation of a verbal order issued to Dagmar Hargreaves on July 13, 2023

Order amended April 3, 2024.

The date for completion for the work referred to in paragraph 1 has been amended to reflect the completion of the installation of the water treatment systems and their approvals by a Public Health Inspector.

Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Template revised October 13, 2022

Olds • Olds Campus Community Health Centre • Environmental Public Health

Suite 2029, 4500 50 Street, Olds, Alberta, Canada T4H 1R6

<https://www.ahs.ca/eph>

AMENDED