

## ORDER OF AN EXECUTIVE OFFICER NOTICE OF CLOSURE

**To:** Town of Killam  
"the Owner"

**RE:** The "Whirlpool" located in Killam, Alberta and municipally described as:  
Killam AgriPlex, 5175 51 Avenue

**WHEREAS** I, an **Executive Officer** of **Alberta Health Services**, have inspected and received a report about the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

**AND WHEREAS** such inspection and report disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. The automated controller for the whirlpool is in disrepair and chlorine was being added manually to the pool. This caused the sample, collected on Tuesday March 31, 2026, to be unsuitable for testing due to excessive chlorine.

**AND WHEREAS** such inspection and report disclosed that the following breaches of the Public Health Act and the Public Swimming Pools Regulation, Alberta Regulation 204/2014 and the Pool Standards there under exist in and about the above noted premises, namely:

- a. The automated controller for the whirlpool is in disrepair and chlorine was being added manually to the pool. This caused the sample, collected on Tuesday March 31, 2026, to be unsuitable for testing due to excessive chlorine. This is in contravention of section 13(3)(b) of the Public Swimming Pools Regulation, which states "the free chlorine residual referred to in subsection (2) must be achieved using a mechanical feeder that provides a consistent, adequate concentration of disinfectant." This is also in contravention of section 13(1) of the Public Swimming Pools Regulation, which states "subject to section 12(2), water in a public swimming pool must be continuously disinfected when in use."

**AND WHEREAS**, by virtue of the foregoing, the above noted premises are hereby declared to be **Closed**.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately close the above noted premises.
2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
  - a. Ensure the automated controller system is repaired and in proper working condition.

- b. Ensure all chemical parameters of water are in accordance with the requirements specified in the Pool Standard.
  - c. A satisfactory water result must be achieved.
3. That until such time as the work referred to above is completed to the satisfaction of an Executive Officer of Alberta Health Services; the above noted premises shall remain closed.

The above conditions were noted at the time of inspection and receipt of the report and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Camrose, Alberta, April 01, 2026

Confirmation of a verbal order issued to Cristen Kinzer on April 01, 2026.

Executive Officer  
Alberta Health Services

You have the right to appeal

A person who      a) is directly affected by a decision of a Regional Health Authority, and  
                                 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board  
c/o Central Reception  
Main Floor, ATB Place North Tower  
10025 Jasper Avenue NW  
Edmonton, Alberta, T5J 1S6  
Phone: 780-222-5186  
Fax: 780-422-0914  
Email: [HealthAppealBoard@gov.ab.ca](mailto:HealthAppealBoard@gov.ab.ca)  
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Template revised April 17, 2025