

ORDER OF AN EXECUTIVE OFFICER

To: Salty Cat Inc.
Jasmine Burton
Wayne Burton
"the Owners"

Ben Holthe
Ashley Holthe
"the Operators"

RE: The recreation area located in Stettler County, Alberta and municipally described as:
Lazy River RV Resort, Plan 1523551 Block 1 Lot 2, SW-34-38-22 W4M

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have received reports about the above noted premises pursuant to the provisions of the **Public Health Act**, RSA 2000, c. P-37, as amended;

AND WHEREAS such reports disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. The water serving Lazy River RV Resort may be unsafe for human consumption as indicated by the presence of total coliform bacteria in drinking water samples collected on August 12 and August 19, 2026.

AND WHEREAS such reports disclosed that the following breaches of the Public Health Act, the Recreation Area Regulation, Alberta Regulation 198/2004 and the Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in and about the above noted premises, namely:

- a. The water serving Lazy River RV Resort may be unsafe for human consumption as indicated by the presence of total coliform bacteria in drinking water samples collected on August 12 and August 19, 2026. This is in contravention of the Nuisance and General Sanitation Regulation, AR 243/2003 Section 11, which states "Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable." This is also in contravention of the Recreation Area Regulation, AR 198/2004 Section 7(1), which states "If a recreation area supplies water a) for human consumption, b) to a sink or shower facility, or c) through hook up to a recreation vehicle, the water must be potable and the requirements set out in subsection (2) must be met in respect of the potable water."

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately issues a Boil Water Advisory to all users of the above noted water supply.

2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Advise all affected users of the water supply that water used for drinking, making infant formula and juices, cooking, making ice, washing fruits and vegetables, brushing teeth, must be boiled for at least 1 minute prior to use.
 - b. Post clear signage at all locations where water from the aforementioned supply is accessible to the public, advising users that the water is not safe for consumption. Additionally, ensure that hand sanitizer containing 60% to 90% alcohol is provided at all handwashing stations.
3. Shock chlorinate the drinking water well and distribution system.
4. Assess the water system to identify any potential causes of contamination and conduct any maintenance or treatment required.
5. Once the above work has been completed, submit two (2) sets of microbiological water samples to the Provincial Laboratory of Public Health. The samples must be collected at least 24 hours apart. All water sample results must be satisfactory and confirm the absence of Total Coliforms and E. coli.
6. That, until such time as the work referred to above is completed to the satisfaction of the undersigned, or an Executive Officer of Alberta Health Services, this order shall remain in effect.

The above conditions were noted at the time of receipt of the reports and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Red Deer, Alberta, August 24, 2026.

Confirmation of a verbal order issued to Ben Holthe on August 21, 2026.

Executive Officer
Alberta Health Services

If you have any questions regarding the order, contact Environmental Public Health at 1-833-476-4743 or
<https://www.albertahealthservices.ca/eph/eph.aspx>

You have the right to appeal

A person who is directly affected by a decision may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Template revised June 2, 2026