ORDER OF AN EXECUTIVE OFFICER
NOTICE OF CLOSURE

To: City of Camrose
"the Owner"

RE: The "pool" located in Camrose, Alberta and municipally described as:
Mayer Aquatic Centre – Whirlpool, 5600 44 Avenue

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

a. The pool's automated chemical monitoring and dosing system is not operable and is unable to continuously monitor, dose, and disinfect the whirlpool.
b. The whirlpool's pH was measured to be between 7.8 and 8.0.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Public Swimming Pools Regulation, Alberta Regulation 204/2014 and the Pool Standards there under exist in and about the above noted premises, namely:

a. The pool's automated chemical monitoring and dosing system is not operable and is unable to continuously monitor, dose, and disinfect the whirlpool. This contravenes sections 13 and 15 of the Public Swimming Pools Regulation, which state that: "water in a public swimming pool must be continuously disinfected when in use," and that "a public swimming pool must be equipped with automated chemical feeding and monitoring equipment for pH and chlorine."
b. The whirlpool's pH was measured to be between 7.8 and 8.0. This contravenes section 4.4 of the Pool Standards, which states that: "the pH of the water in a public swimming pool must be maintained at no less than 6.8 and no greater than 7.6."

AND WHEREAS, by virtue of the foregoing, the above noted premises are hereby declared to be **Closed**.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately close the above noted premises.

2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:

a. Repair the automated computer control system for the whirlpool to allow for automated measurement, dosing and control of the chlorine concentration and pH of the water.
b. Rebalance the pool water chemistry to align with legislative requirements.
c. Submit a satisfactory bacteriological water test for the whirlpool.

3. That until such time as the work referred to above is completed to the satisfaction of an Executive Officer of Alberta Health Services; the above noted premises shall remain closed.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Wetaskiwin, Alberta, November 13, 2026.

Confirmation of a verbal order issued to KB Dumas on November 12, 2026.

Executive Officer
Alberta Health Services

If you have any questions regarding the order, contact Environmental Public Health at 1-833-476-4743 or https://www.albertahealthservices.ca/eph/eph.aspx

You have the right to appeal

A person who is directly affected by a decision may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: https://www.alberta.ca/public-health-appeal-board.aspx

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or https://www.alberta.ca/alberta-kings-printer.aspx.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or https://www.alberta.ca/alberta-kings-printer.aspx.

Copies of standards are available by visiting: https://www.alberta.ca/health-standards-and-guidelines.aspx

Template revised June 2, 2026