

ORDER OF AN EXECUTIVE OFFICER

To: Douglas MacLaine-Pont
Labyrinth Lake Lodge Ltd.
Offerdale Farms Ltd.
"the Owners"

RE: Those housing premises located in Wetaskiwin County, Alberta and municipally described as:
One Room Cabin
224041 Township Road 481
NW-05-48-22-W4M

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. There are no smoke alarms, in this rental unit.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Housing Regulation, Alberta Regulation 173/99, and the Minimum Housing and Health Standards exist in and about the above noted premises, namely:

- a. There are no smoke alarms, in this rental unit. This condition is contrary to the requirements of the Minimum Housing and Health Standards, Section 12(a) that states, "Smoke alarms within dwellings shall be installed between each sleeping area and the remainder of the suite and, where hallways serve the sleeping areas; the smoke alarms shall be installed within the hallway. Smoke alarms shall be operational and in good repair at all times."

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. There must be at least one operating, functional and properly located smoke alarm for this the dwelling.
2. The work referred to in paragraph 1 shall be completed by September 30, 2017.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Wetaskiwin, Alberta, August 18, 2017.

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, Telus Plaza North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <http://www.health.alberta.ca/about/PHAB.html>

A Notice of Appeal form may be obtained by contacting Alberta Health Services at 780-342-0122 or by contacting the Public Health Appeal Board.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or www.qp.gov.ab.ca.

Health Legislation and regulations are available for purchase. Please contact Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or www.qp.gov.ab.ca.

Copies of standards are available by contacting the Health Protection Branch of Alberta Health at 780-427-4518 or by visiting: www.health.alberta.ca/about/health-legislation.html

Template revised December 13, 2016

Wetaskiwin • Wetaskiwin Community Health Centre • Environmental Public Health

5610 - 40 Avenue, Wetaskiwin, Alberta, Canada T9A 3E4

www.albertahealthservices.ca/eph.asp