

ORDER OF AN EXECUTIVE OFFICER Boil Water Order

To: Jonah Holdings Ltd.

Pipestone Links Ltd. Jack Hendriks Anita Hendriks

"the Owners"

RE: The Drinking Water Supply located in County of Wetaskiwin, Alberta and municipally

described as: Pipestone Links Golf Course, 472051A Range Road 242A.

WHEREAS I, an Executive Officer of Alberta Health Services, have received reports about the above noted drinking water supply pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such reports disclosed that the following conditions exist in and about the above noted drinking water supply which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

a. The water supply serving the food establishment may be unsafe for human consumption as indicated by the presence of Total Coliform bacteria in samples collected on August 26, 2025 (Total Coliforms – Present) and September 2, 2025 (Total Coliforms – Present).

AND WHEREAS such reports disclosed that the following breaches of the Public Health Act Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in and about the above noted Drinking Water Supply, namely:

a. The water supply serving the food establishment may be unsafe for human consumption as indicated by the presence of Total Coliform bacteria in samples collected on August 26, 2025 (Total Coliforms – Present) and September 2, 2025 (Total Coliforms – Present). This is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states "Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable".

AND WHEREAS by virtue of the foregoing, the above noted Drinking Water Supply is hereby declared **unfit for human consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

- 1. That the Owner immediately issues a Boil Water Advisory to all users of the above noted Drinking Water Supply.
- 2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted drinking water supply, namely:

- a. Ensure that water used for drinking or food preparation is boiled for at least 1 minute prior to use or use an alternate potable water supply (e.g. bottled water).
- b. Shock chlorinate the water well system and flush the lines.
- c. Submit bacteriological water samples that do not show the presence of Total Coliforms or E. coli bacteria. Two consecutive satisfactory sample results, taken at least 24 hours apart, will need to be obtained in order to comply.
- 3. The work referred to in paragraph 2 shall be completed by as soon as possible.
- 4. That, until such time as the work referred to in paragraph 2 is completed to the satisfaction of the undersigned, or an executive officer of Alberta Health Services, that this order shall remain in effect.

The above conditions were noted at the time of receipt of the reports and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Wetaskiwin, Alberta, September 5, 2025.

Confirmation of a verbal order issued to Jack Hendriks on September 4, 2025.

Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and

b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board c/o Central Reception Main Floor, ATB Place North Tower 10025 Jasper Avenue NW Edmonton, Alberta, T5J 1S6 Phone: 780-222-5186

Phone: 780-222-518 Fax: 780-422-0914

Email: HealthAppealBoard@gov.ab.ca

Website: https://www.alberta.ca/public-health-appeal-board.aspx

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or https://www.alberta.ca/alberta-kings-printer.aspx.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or https://www.alberta.ca/alberta-kings-printer.aspx.

Copies of standards are available by contacting the Health Protection Branch of Alberta Health at 780-427-4518 or by visiting: https://www.alberta.ca/health-standards-and-guidelines.aspx

Template revised April 17, 2025

Wetaskiwin • Wetaskiwin Community Health Centre • Environmental Public Health
5610 40 Avenue, Wetaskiwin, Alberta, Canada T9A 3E4

www.ahs.ca/eph