

ORDER OF AN EXECUTIVE OFFICER NOTICE OF CLOSURE

To: 2784993 Alberta Ltd.
Jason Wight
Patricia Phillips
“the Owners”

RE: The “pool” located in Red Deer, Alberta and municipally described as:
Prairie Crest Hotel Red Deer – Whirlpool, #1000 5001 19 Street

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. The whirlpool is in disrepair; a leak along the distribution line is causing water loss from the basin.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Public Swimming Pools Regulation, Alberta Regulation 204/2014 and the Pool Standards there under exist in and about the above noted premises, namely:

- a. The whirlpool is in disrepair; a leak along the distribution line is causing water loss from the basin. This condition is in contravention of section 11 (b) of the Public Swimming Pools Regulation, which states: “In accordance with the Pool Standards, a pool must be maintained in a state of repair that provides for the safe and sanitary operation of the pool.”

AND WHEREAS, by virtue of the foregoing, the above noted premises are hereby declared to be **Closed**.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately close the above noted premises.
2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Identify the source of the leak and repair as necessary. Please provide findings to Environmental Public Health.
 - b. Chemically balance the whirlpool water.

- c. Collect and submit a bacteriological water sample from the whirlpool to the Provincial Laboratory, as a satisfactory water sample is required prior to re-opening the whirlpool.
3. That until such time as the work referred to above is completed to the satisfaction of an Executive Officer of Alberta Health Services; the above noted premises shall remain closed.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Red Deer, Alberta, April 10, 2026

Confirmation of a verbal order issued to General Manager, Dodie Gladue on April 10, 2026.

Order amended April 21, 2026, only to reflect change to ownership and business trade name.

Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Template revised April 17, 2025

AMENDED