

ORDER OF AN EXECUTIVE OFFICER

To: Salem Acres Bible Camp Association
Peter Andrusiak
Eldon Siemens
“the Owners”

RE: The food establishment located in Red Deer County, Alberta and municipally described as: Salem Acres Bible Camp, 21442 Highway 590.

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have received reports about the above noted premises pursuant to the provisions of the **Public Health Act**, RSA 2000, c. P-37, as amended;

AND WHEREAS such reports disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. The water serving Salem Acres Bible Camp may be unsafe for human consumption as indicated by the presence of Total Coliform bacteria in 2 consecutive drinking water samples collected on August 20, 2025, and May 20, 2026.

AND WHEREAS such reports disclosed that the following breaches of the Public Health Act and the Food Regulation, Alberta Regulation 31/2006 and the Food Retail and Foodservices Code, and the Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in and about the above noted premises, namely:

- a. The water serving Salem Acres Bible Camp may be unsafe for human consumption as indicated by the presence of Total Coliform bacteria in 2 consecutive drinking water samples collected on August 20, 2025, and May 20, 2026. This condition is in contravention of the Nuisance and General Sanitation Regulation, AR 243/2003 Section 11, which states: “Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable.”

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Advise all affected users of the water supply that water used for drinking, making infant formula and juices, cooking, making ice, washing fruits and vegetables, brushing teeth, must be boiled for at least 1 minute prior to use.
 - b. Post clear signage at all locations where water from the aforementioned supply is accessible to the public, advising users that the water is not safe for consumption. Additionally, ensure that hand sanitizer containing 60% to 90% alcohol is provided at all handwashing stations.

- c. Shock chlorinate the wells and thoroughly flush and disinfect all water lines in the distribution system.
 - d. Drain, inspect, clean and disinfect the cistern.
 - e. Install a proper cap for the old well head.
 - f. Submit two sets of satisfactory bacteriological water samples from representative locations, taken at least 24 hours apart, that show no presence of Total Coliforms or E.coli.
2. That, until such time as the work referred to in paragraph 1 is completed to the satisfaction of the undersigned, or an executive officer of Alberta Health Services, that this order shall remain in effect.

The above conditions were noted at the time of receipt of the reports and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Red Deer, Alberta, May 29, 2026.

Confirmation of a verbal order issued to Anthony Martin on May 22, 2026.

Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Template revised April 17, 2025