

ORDER OF AN EXECUTIVE OFFICER

To: Alberta Hospitality Ltd.
"the Owner"

Sanjay Yadav
"the Director"

RE: The "pools" located in Drayton Valley, Alberta and municipally described as:
Service Plus Inns & Suites Drayton Valley – Pool & Whirlpool, 5704 Power Centre
Boulevard

WHEREAS I, an **Executive Officer of Alberta Health Services**, have inspected the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. There is no certified pool operator to oversee the daily operation and maintenance of the facility.
- b. Written policies and plans have not been developed for pool safety and supervision, responses to water quality issues, including fecal contamination, and general sanitation.
- c. The Anti-Entrapment Compliance Plan for Public Swimming Pools is incomplete.
- d. The facility cannot calculate their maximum flow rate for the pool and whirlpool.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Public Swimming Pools Regulation, Alberta Regulation 204/2014 and the Pool Standards there under exist in and about the above noted premises, namely:

- a. There is no certified pool operator to oversee the daily operation and maintenance of the facility. This is in contravention of Section 1.1 of the Pool Standards, which states, "The pool operator must be certified by an organization that is on the List of Approved Pool Operator Education Organizations approved by the Minister."
- b. Written policies and plans have not been developed for pool safety and supervision, responses to water quality issues, including fecal contamination, and general sanitation. This is in contravention of Section 24(1) of the Public Swimming Pools Regulation, which states that, "The owner or the owner's agent, if any, must develop and maintain written policies and implement plans for those policies in accordance with the Pool Standards respecting a) safety and supervision of all patrons, c) response to water quality issues, including fecal contamination, and d) general sanitation."
- c. The Anti-Entrapment Compliance Plan for Public Swimming Pools is incomplete. This is in contravention of Section 9.1 of the Pool Standards, which states, "Every owner or owner's agent, if any, must assess anti-entrapment risks, develop and implement an appropriate anti-entrapment plan to meet the requirements of this section."

- d. The facility cannot calculate their maximum flow rate for the pool or whirlpool. This is in contravention of Section 9.3.3 of the Pool Standards, which states, "Pursuant to Section 9.3.2, where an operator is unable to calculate the maximum flow rate, the maximum flow rate must be determined by a professional engineer."

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Ensure that the staff member overseeing the daily operation and maintenance of the facility is certified as a pool operator by an organization that has been approved by the Minister.
 - b. Develop written policies and plans for pool safety and supervision, responses to water quality issues, including fecal contamination, and general sanitation.
 - c. Submit a complete Anti-Entrapment Compliance Plan for Public Swimming Pools.
 - d. Contract a professional engineer to calculate the maximum flow rate for the pool and whirlpool.
2. The work referred to in paragraph 1 shall be completed by November 13, 2026.
 - a. Until such time that the work referred to in paragraph 1 has been completed, the Owner or owner's agent shall send a weekly summary of the facility's chemical test results (Free Available Chlorine, Combined Chlorine, pH, and Total Alkalinity) to the Executive Officer.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Drayton Valley, Alberta, September 14, 2026

Executive Officer
Alberta Health Services

If you have any questions regarding the order, contact Environmental Public Health at 1-833-476-4743 or <https://www.albertahealthservices.ca/eph/eph.aspx>

You have the right to appeal

A person who is directly affected by a decision may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186

Fax: 780-422-0914

Email: HealthAppealBoard@gov.ab.ca

Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Template revised June 2, 2026