

ORDER OF AN EXECUTIVE OFFICER

To: Sehaj & Diya Holdings LTD.
"the Owner"

Kamaljit Singh
"the Owner"

Shalki Rana
"the Owner"

RE: Those housing premises located in Edmonton, Alberta and municipally described as:
11935 101 Street NW, Edmonton, Alberta, T5G 2B8

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. The building is not supplied with hot running water.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Housing Regulation, Alberta Regulation 173/99, and the Minimum Housing and Health Standards exist in and about the above noted premises, namely:

- a. The building is not supplied with hot running water. This is in contravention of section 9(a) of the Minimum Housing and Health Standards which states that all hot running water shall be maintained at a temperature of not less than 46 degrees C (114°F), and not more than 60 degrees C (140°F) measured at the plumbing fixture.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Repair the building plumbing system such that all plumbing fixtures can supply hot running water at a temperature of not less than 46 degrees C (114°F), and not more than 60 degrees C (140°F).
2. The work referred to in paragraph 1 shall be completed by July 20, 2026.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Edmonton, Alberta, July 15, 2026.

Confirmation of a verbal order issued to Kamaljit Singh on July 15, 2026.

Executive Officer
Alberta Health Services

If you have any questions regarding the order, contact Environmental Public Health at 1-833-476-4743 or
<https://www.albertahealthservices.ca/eph/eph.aspx>

You have the right to appeal

A person who is directly affected by a decision may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or
<https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Order of an Executive Officer

RE: Those premises located in Edmonton, Alberta and municipally described as: 11935 101 Street NW, Edmonton, Alberta, T5G 2B8

Page 3 of 3

Edmonton • Environmental Public Health

#900 North Tower – 10030 107 Street NW, Edmonton, AB, Canada, T5J 3E4

<https://www.ahs.ca/eph>