

ORDER OF AN EXECUTIVE OFFICER

To: Mike Everitt Nazly Taheri
 "the Owner" "the Owner"

RE: Those housing premises located in Edmonton, Alberta and municipally described as:
 12936 118 Avenue NW

WHEREAS I, an **Executive Officer of Alberta Health Services**, have inspected the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. There was leaking/dripping from the ceiling of basement common hallway area, and there were 7 buckets on the floor to catch the water.
- b. There was extensive water damage and mold growth on the basement common hallway ceilings.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Housing Regulation, Alberta Regulation 173/99, and the Minimum Housing and Health Standards exist in and about the above noted premises, namely:

- a. Items (a) is in contravention of section III (6) of the Minimum Housing and Health Standards which states that: Every housing premises shall be connected to the public sewage system, or to an approved private sewage disposal system. (a) The plumbing system and the sanitary drainage system or private sewage disposal system, as the case may be, including drains, fixtures, traps, vents, stacks, waste disposal facilities, pumpout sewage holding tanks, septic tanks and the disposal system shall be maintained in a proper operating condition. (c) All plumbing fixtures shall be serviceable, free from leaks, trapped and vented to the outside.
- b. Items (b) is in contravention of section III 1(c) of the Minimum Housing and Health Standards which states: Building materials that have been damaged or show evidence of rot or other deterioration shall be repaired or replaced.
- c. Items (b) is also in contravention of section III (5) of the Minimum Housing and Health Standards which states that: All walls, windows, ceilings, floors, and floor coverings shall be maintained in good repair, free of cracks, holes, loose or lifting coverings and in a condition that renders it easy to clean".
- d. Item (b) is further in contravention of section 5(2) of the Housing Regulation that states that: No person shall cause or permit any condition in housing premises that is or might become injurious or dangers to the public health, including any condition that may hinder in any way the prevention or suppression of disease.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:

- a. Retain the services of an Environmental Consultant or Industrial/Occupational Health Hygienist, that must be approved by Alberta Health Services and prior to the commencement of renovation or repairs:

As this premise was built prior to 1990, the presence of asbestos within building materials is likely thus precautions must be taken. The consultant must assess the conditions within the above noted premises including performing applicable sampling for asbestos containing materials.

In the event asbestos is present provide Environmental Public Health with a written asbestos management/abatement plan in accordance with the Alberta Occupational Health and Safety Code for Asbestos abatement. Ensure proper removal/handling of impacted materials follow current codes and standards.

Have the environmental consultant assess the conditions within the above noted premises for all water damaged materials and mold. A full pre mold remediation inspection report is required. At a minimum the report must describe the building construction, finishes, materials and components and recommendations for restoration. All hazardous building materials are to be properly managed and disposed of in accordance with government standards and guidelines and industry codes of practice. Once the materials have been removed and a post mold remediation report is required this will include photographic evidence that all moldy material has been removed and environmental air quality sampling. Testing and reporting shall follow the requirements outlined in Alberta Health Services' Fungal Air Testing Protocol.

- b. Hire a qualified plumber to assess the conditions of the plumbing system and conduct any necessary repairs to correct the sources of water infiltration to the basement. Ensure all the plumbing fixtures include the drains are serviceable, free from leaks, trapped and vented to the outside.
- c. Remove and replace all damaged or moldy material includes all damaged ceilings, drywalls and floor coverings. Ensure all walls, ceilings, floors, and floor coverings are maintained in good repair, free of cracks, holes, loose or lifting coverings and in a condition that renders it easy to clean.

2. The work referred to in paragraph 1 shall be completed by:

- a. Item b must be completed immediately.
- b. Item a and c must be corrected by May 15, 2023.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Edmonton, Alberta, May 1, 2023

Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Edmonton • Environmental Public Health

Suite 700, 10055 106 Street NW, Edmonton, AB, Canada T5J 2Y2

www.albertahealthservices.ca/eph.asp