



ORDER OF AN EXECUTIVE OFFICER Boil Water Order

To: Matrix Marine Equipment Ltd.
Kenneth (& Donna) Nelson
"the Owner"

RE: The Drinking Water Supply located in the City of Edmonton, Alberta and municipally described as **Spruce Valley Events at Shalom Park, 20750 – 57 Avenue Southwest, Edmonton, Alberta T7Y 1A8**

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted drinking water supply pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted drinking water supply which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. A groundwater assessment completed in July 2024 determined the system to be vulnerable to environmental contamination.
- b. Water supplying the premises may be unsafe for human consumption as indicated by a water sample collected on July 6, 2026, that showed the presence of Total Coliform and E coli bacteria.
- c. Water supplying the premises may be unsafe for human consumption as indicated by a water sample collected on July 8, 2026, that showed the presence of Total Coliform and E coli bacteria.
- d. Water supplying the premises may be unsafe for human consumption as indicated by water sample collected on August 10, 2026, that showed the presence of Total Coliform and E coli bacteria.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in and about the above noted Drinking Water Supply, namely:

- a. A groundwater assessment completed in July 2024 determined the system to be vulnerable to environmental contamination, which is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states "Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable".
- b. Water supplying the premises may be unsafe for human consumption as indicated by a water sample collected on July 6, 2026, that showed the presence of Total Coliform and E coli bacteria which is in contravention of the Nuisance and General Sanitation Regulation

Section 11, which states “Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable”.

- c. Water supplying the premises may be unsafe for human consumption as indicated by a water sample collected on July 8, 2026, that showed the presence of Total Coliform and E coli bacteria, which is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states “Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable”.
- d. Water supplying the premises may be unsafe for human consumption as indicated by water sample collected on August 10, 2026, that showed the presence of Total Coliform and E coli bacteria, which is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states “Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable”.

AND WHEREAS by virtue of the foregoing, the above noted Drinking Water Supply is hereby declared **unfit for human consumption**; NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owners immediately issue a Boil Water Advisory to all users of the above noted Drinking Water Supply.
2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted drinking water supply, namely:
 - a. Post do not drink advisory signs at all water fixtures.
 - b. Ensure that all users of the facility, including staff, have access to potable water from an approved source, or water that has been boiled for at least one minute, until an Executive Officer of Alberta Health Services confirms the water is safe for human consumption.
 - c. Provide hand sanitizer of at least 60% alcohol content with either a NPN (Natural Product Number) or DIN (Drug Identification Number) at handwashing sinks.
 - d. Ensure food processing and preparation is done with potable water from an approved source or with water that has been boiled for one minute.
 - e. Discard ice and any other food or drink items made with untreated water which will be served uncooked.
 - f. Ensure that all utensils, counters, and food contact surfaces are sanitized using an approved sanitizing step.
 - g. Discontinue use of pop machines, ice machines, and any other equipment directly plumbed to the water system.
 - h. Install a disinfection treatment system that meets AHS requirements or install cistern to supply potable water.
 - i. Flush all water lines once the disinfection treatment system or cistern installation is completed
 - j. Once items h. and i. are completed, submit two sets of microbiological water samples at least 24 hours apart to the Provincial Laboratory of Public Health from different locations within the distribution system. All water samples results must be satisfactory and must show absence of Total Coliform bacteria and E.coli bacteria.

Order of An Executive Officer – Boil Water Order

RE: The Drinking Water Supply located in the City of Edmonton, Alberta and municipally described as Spruce Valley Events at Shalom Park, 20750 – 57 Avenue Southwest, Edmonton, Alberta T7Y 1A8

Page 3 of 4

3. That, until such time as the work referred to in paragraph 2 is completed to the satisfaction of the undersigned, or an executive officer of Alberta Health Services, that this order shall remain in effect.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED Leduc, Alberta, September 9, 2026.

Confirmation of a verbal order issued to September 4, 2026.


Public Health Inspector
Executive Officer

Order of An Executive Officer – Boil Water Order

RE: The Drinking Water Supply located in the City of Edmonton, Alberta and municipally described as Spruce Valley Events at Shalom Park, 20750 – 57 Avenue Southwest, Edmonton, Alberta T7Y 1A8

Page 4 of 4

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by contacting the Health Protection Branch of Alberta Health at 780-427-4518 or by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Spruce Grove • Stan Woloshyn Building • Environmental Public Health

205 Diamond Avenue, Spruce Grove, Alberta, Canada T7X 3A8

www.ahs.ca/eph