

ORDER OF AN EXECUTIVE OFFICER Boil Water Order

To: Hilltop Estates
"the Owner"

RE: The Drinking Water Supply located in County of Grande Prairie No.1, Alberta and municipally described as: Hilltop Estates Water Coop

WHEREAS I, an **Executive Officer of Alberta Health Services**, have or received a report about the above noted drinking water supply pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such report disclosed that the following conditions exist in and about the above noted drinking water supply which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. Drinking water in the distribution system may be unsafe for consumption due to a water main break resulting in complete loss of pressure for the entire distribution system for an extended period.

AND WHEREAS such report disclosed that the following breaches of the Public Health Act Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in and about the above noted Drinking Water Supply, namely:

Drinking water in the distribution system may be unsafe for consumption due to a water main break resulting in complete loss of pressure for the entire distribution system for an extended period which is in contravention of Section 11 of the Nuisance and General Sanitation Regulation, which states: "Where a person provides a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable."

AND WHEREAS by virtue of the foregoing, the above noted Drinking Water Supply is hereby declared **unfit for human consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately issues a Boil Water Advisory to all users of the above noted Drinking Water Supply.
2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted drinking water supply, namely:
 - a. Locate the leak and complete the necessary repairs of the potable water infrastructure in accordance with Alberta Environment and Protected Areas (AEPA)

requirements and directions.

- b. Complete the flushing of the potable water distribution system in accordance with AEPA direction
- c. After flushing of the distribution system has been completed, two sets of satisfactory bacteriological water samples taken at least 24 hours apart are required. Bacteriological water samples must be submitted to the Alberta Provincial Laboratory of Public Health and must be representative of the potable water distribution system.

3. That, until such time as the work referred to in paragraph 2 is completed to the satisfaction of the undersigned, or an executive officer of Alberta Health Services, that this order shall remain in effect.

The above conditions were noted at the time of receipt of the report and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Grande Prairie, Alberta, December 24, 2025

Confirmation of a verbal order issued to Paul Cincurak on December 23, 2025.

Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Order of An Executive Officer – Boil Water Order

RE: The Drinking Water Supply located in County of Grande Prairie No.1, Alberta and municipally described as: Hilltop Estates Water Coop, 715010 Range Road 84, County of Grande Prairie (North of Range Road 84, just off of Highway 43)

Page 3 of 3

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by contacting the Health Protection Branch of Alberta Health at 780-427-4518 or by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Template revised April 17, 2025

Copy Alberta Environment and Protected Areas (AEPA)

Grande Prairie • Grande Prairie Public Health Centre • Environmental Public Health

10320 – 99 Street Grande Prairie AB Canada T8V 6J4

www.ahs.ca/eph

PSD-0315-202205