

ORDER OF AN EXECUTIVE OFFICER Boil Water Order

To: Municipal District of Greenview No.16
“the Owner”

RE: The Drinking Water Supply located in RidgeValley, Alberta and municipally described as:
RidgeValley Water Treatment Plant/ Crooked Creek Truck Fill, SE 26 71 26 W5M,
Valleyview, Alberta.

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted drinking water supply pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted drinking water supply which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. Possible bacteriological contamination to water distribution system due to a flood in the water treatment plant.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in and about the above noted Drinking Water Supply, namely:

- a. Surface run-off water entered the water treatment plant, which caused flooding and contamination of drinking water supply. The contamination of Drinking Water is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states “Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable”.

AND WHEREAS by virtue of the foregoing, the above noted Drinking Water Supply is hereby declared **unfit for human consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately issues a Boil Water Advisory to all users of the above noted Drinking Water Supply.
2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted drinking water supply, namely:
 - a. Completes a thorough clean and disinfection of water treatment plant in consultation with Alberta Environment and Parks
 - b. Complete a sequential flush of the distribution system from closest to furthest end-points to remove any potentially contaminated water.

- c. After flushing the distribution system, monitor and report (to AHS Environmental Public Health – North Zone) the chlorine residual and turbidity levels at representative points in the distribution system and submit two sets of bacteriological samples, collected at least 24 hours apart from representative locations throughout the distributions system.
3. That, until such time as the work referred to in paragraph 2 is completed to the satisfaction of the undersigned, or an executive officer of Alberta Health Services, that this order shall remain in effect.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Grande Prairie, Alberta, February, 11th, 2022.

Confirmation of a verbal order issued to Eric Ungstad on February, 10th, 2022.

Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting Alberta Health Services at 780-342-0122 or by contacting the Public Health Appeal Board.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or www.qp.gov.ab.ca.

Health Legislation and regulations are available for purchase. Please contact Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or www.qp.gov.ab.ca.

Copies of standards are available by contacting the Health Protection Branch of Alberta Health at 780-427-4518 or by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Template revised Feb 20, 2020

Copy Alberta Environment and Parks

Grande Prairie • Grande Prairie Provincial Building • Environmental Public Health

10320 99 Street Grande Prairie, Alberta Canada T8V 6J4

www.albertahealthservices.ca/eph.asp