

**ORDER OF AN EXECUTIVE OFFICER
CLOSED FOR TENANT ACCOMMODATION PURPOSES
ORDER TO VACATE**

To: Calvin Adams
Judith Adams
George Adams
“the owner”

And To: All Occupant(s) of the following Housing premises:

RE: Those garage premises located in Lethbridge Alberta and municipally described as:
640 12 A Street North

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted premises pursuant to the provisions of the **Public Health Act**, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. Inadequate plumbing system and water supply. No permanent hot or cold running water or drains were available. A garden hose was strung through the window into the garage unit and the sink was not connected to a drain.
- b. Lack of a washroom.
- c. No heating.
- d. Lack of a kitchen facility. Stove was present.
- e. Electrical deficiencies including switch covers.
- f. No smoke alarms.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Housing Regulation, Alberta Regulation 173/99, and the Minimum Housing and Health Standards exist in and about the above noted premises, namely:

- a. Section 2(2)(a) of the Nuisance and General Sanitation Regulation which states that: A person who creates, commits or maintains any premises in a condition that is or might become injurious or dangerous to the public health or that might hinder in any manner the prevention or suppression of disease is deemed to have created, committed or maintained a nuisance.
- b. Inadequate plumbing system, which is in contravention of section IV(6) of the Minimum Housing and Health Standards which states that: Every housing premises shall be

- connected to the public sewage system, or to an approved private sewage disposal system.
- c. Lack of a washroom, which is in contravention of section IV(7) of the Minimum Housing and Health Standards which states that: Except where exempt by regulation, every housing premises shall be provided with plumbing fixtures of an approved type consisting of at least a flush toilet, a wash basin, and a bathtub or shower.
 - d. No heating, which is in contravention of section IV(8)(a)(i) of the Minimum Housing and Health Standards which states that: All heating facilities within a housing premises are to be properly installed and maintained in good working condition, and be *capable* of safely and adequately heating all habitable rooms, bathrooms, and toilet rooms within the building to a temperature of at least 220C(710F), or maintained at a temperature of at least 220C(710F) when the control of the supplied heat in a dwelling is the responsibility of a person other than the occupant.
 - e. Inadequate water supply, which is in contravention of section IV(9) of the Minimum Housing and Health Standards which states that: Every building used in whole or in part, as housing premises shall be supplied with a potable water supply of sufficient volume, pressure and temperature to serve the needs of the inhabitants.
 - f. Electrical deficiencies, which is in contravention of section IV(11) of the Minimum Housing and Health Standards which states that: Every housing premises shall be supplied with electrical service. Outlets, switches and fixtures shall be properly installed and shall be maintained in a good and safe working condition.
 - g. No smoke alarms, which is in contravention of section IV(12) of the Minimum Housing and Health Standards which states that: Smoke alarms within dwellings shall be installed between each sleeping area and the remainder of the suite and, where hallways serve the sleeping areas; the smoke alarms shall be installed within the hallway.
 - h. Lack of a kitchen facility and adequate water supply, which is in contravention of section IV(14)(a)(i) of the Minimum Housing and Health Standards which states that: Every housing premises shall be provided with a food preparation area, which includes: a kitchen sink that is supplied with potable hot and cold water and suitably sized to allow preparation of food, washing utensils and any other cleaning operation.
 - i. Lack of a kitchen facility, which is in contravention of section IV(14)(a)(i) of the Minimum Housing and Health Standards which states that: Every housing premises shall be provided with a food preparation area, which includes: a stove and a refrigerator that are maintained in a safe and proper operating condition. The refrigerator shall be capable of maintaining a temperature of 4 degrees C.

AND WHEREAS, by virtue of the foregoing, the above noted premises are hereby declared to be **Closed for Tenant Accommodation Purposes**.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the occupants vacate the above noted premises on or before May 20, 2015.
2. That the owner immediately undertake and diligently ensure that the garage premises is secured and is not used for human habitation.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Lethbridge, Alberta, May 20, 2015
Confirmation of a verbal order issued to George Adams and Calvin Adams on May 20, 2015.

YOU HAVE THE RIGHT TO APPEAL

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision within ten (10) days after receiving the order to the Public Health Appeal Board located at Reception, Main Floor, Telus Plaza, 10025 Jasper Avenue, Edmonton, Alberta, T5J 1S6, Telephone 780-427-2813 Fax 780-422-0914.

The terms of this Order remain in effect notwithstanding the filing or proposed filing of any such appeal. If you appeal, you may also make an application to the Board for a stay of this Order pending the appeal.

A copy of the Public Health Appeal form may be obtained by contacting Alberta Health Services at 780-342-0122 or the Public Health Appeal Board 780-427-2813.

You are advised that all orders remain in effect pending such an appeal

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or www.qp.gov.ab.ca.

Health Legislation and regulations are available for purchase. Please contact Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or www.qp.gov.ab.ca.

Copies of standards are available by contacting the Health Protection Branch of Alberta Health at 780-427-4518, or by visiting: www.health.alberta.ca/about/health-legislation.html

Copy: City of Lethbridge