

EXECUTIVE OFFICER'S ORDER

To: **Golden Sheaf Recreation Development Society
SW 1/4 11-12-8-W4M
County of Forty Mile No. 8**

RE: **Golden Sheaf Recreation Park Water System**

WHEREAS I, an Executive Officer of Alberta Health Services, have inspected the above premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder the prevention or suppression of disease, namely:

- a. **Raw water is being supplied to users of the campground and to privately owned leased recreational lots.**

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Regulations there under exist in and about the above noted premises, namely:

- a. **Nuisance and General Sanitation Regulation AR 243/2003 section 11** which states that "where a person provides a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable".

NOW THEREFORE, I hereby ORDER and DIRECT:

1. That the owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Take immediate and reasonable action to notify **all** users of this water system that the water is not safe for human consumptions and that the water must be boiled for at least 1 minute rolling boil prior to consumption, or to find an alternate safe water supply for drinking. These measures must remain in place until such time that an Executive Officer of Alberta Health Services notifies you that the water is safe for consumption.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at **Medicine Hat**, Alberta, **July 5, 2012**



Pam Hodgkinson, CPHI(C), BEH(AD), BSc. Micro (IIP)
Executive Officer

Environmental Health Officer

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
b) feels himself aggrieved by the decision

may appeal the decision within ten (10) days after receiving the order to the Public Health Appeal Board located at 24th Floor, Telus Plaza, 10025 - Jasper Avenue, Edmonton, Alberta, T5J 1S6. Telephone (780) 427-2813.

The terms of this Order remain in effect notwithstanding the filing or proposed filing of any such appeal. If you appeal, you may also make an application to the Board for a stay of this Order pending the appeal.

A copy of the Public Health Appeal form may be obtained by contacting Alberta Health Services at (780) 342-0122, or the Public Health Appeal Board (780) 427-2813.

You are advised that all orders remain in effect pending such an appeal

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or www.qp.gov.ab.ca.

Health Legislation and regulations are available for purchase. Please contact Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7) or www.qp.gov.ab.ca.

Copies of standards are available by contacting the Health Protection Branch of Alberta Health & Wellness at (780) 427-4518, or by visiting: www.health.alberta.ca/about/health-legislation.html

Confirmation of an oral boil water order issued to **Shirley Burgess**, at **July 5, 2012** at **1215hrs**.

Copy **Alberta Environment & Water**

Cardston
Community Health
Box 1590
Cardston, AB T0K 0K0
Phone: 403-653-5231
Fax: 403-653-2926

Coaldale
Community Health
Box 1000
Coaldale, AB T1M 1M8
Phone: 403-345-3000
Fax: 403-345-2043

Crowsnest Pass
Community Health
Box 67
Blairmore, AB T0K 0E0
Phone: 403-562-5030
Fax: 403-562-7379

Fort Macleod
Community Health
Box 520
Fort MacLeod, AB T0L 0Z0
Phone: 403-553-5363
Fax: 403-553-2333

Lethbridge
Community Health
801 - 1 Avenue South
Lethbridge, AB T1J 4L5
Phone: 403-388-6689
Fax: 403-328-5934

Pincher Creek
Community Health
Box 1685
Pincher Creek, AB T0K 1W0
Phone: 403-627-1230
Fax: 403-627-5275

Raymond
Community Health
Box 251
Raymond, AB T0K 2S0
Phone: 403-752-5430
Fax: 403-752-4655

Taber
Community Health
5009 - 56 Street
Taber, AB T1G 1M8
Phone: 403-223-4403
Fax: 403-223-8733

Brooks
Community Health
220 - 4 Avenue West
Brooks, AB T1R 0E9
Phone: 403-362-2682
Fax: 403-793-2772

Medicine Hat
Community Health
River Heights Professional Centre
Suite 200, 88 Valleyview Dr. SW
Medicine Hat, AB T1A 8N6
Phone: 403-502-8205
Fax: 403-502-8256