

**ORDER OF AN EXECUTIVE OFFICER
CLOSED FOR TENANT ACCOMMODATION PURPOSES
ORDER TO VACATE (Amended April 1, 2026)**

To: Crowsnest Management Holdings Ltd.
“the Owner”

Harry Kuryluk
“the Owner”

Grant Kuryluk
“the Owner”

And To: All Occupants of the following Housing premises:

RE: Those housing premises located in Municipality of Crowsnest Pass, Alberta and municipally described as: Lots: 11-14, Block: 2, Plan: 33191, 2022 & 2034-129 Street, Blairmore, AB, **Unit 3**.

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted premises pursuant to the provisions of the **Public Health Act**, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, in contravention of the Public Health Act and Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 namely:

- a. The living room window had no screen.
- b. The living room was the only sleeping area with a bed. The window was 2.4 square feet, which was too small for egress.
- c. The bathroom plumbing was in poor repair including:
 - i. The hand sink was rusting.
- d. The radiator cover was missing pieces.
- e. The electrical system was in poor repair including:
 - i. A ceiling light fixture was not attached to the junction box and hung by the wires.
 - ii. The mercury thermostat was missing a cover.
 - iii. Half of the bathroom's vanity light was not functional.
- f. The smoke detector was missing.

- g. The unit was very dirty including:
 - i. There was an extreme layer of grime on most wall or common touch objects.
 - ii. The living room carpet was stained and crunchy due to uncleanness.
 - iii. The ceiling fan had a heavy layer of dust on it.
- h. The unit had rodent activity and harborage including:
 - i. Mouse droppings were found at many locations such as the stove drawer, bedroom, and kitchen cabinet.
 - ii. The bedroom was full of storage with mouse droppings. There were obvious points of rodent entry around the radiator pipe in the wall.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Housing Regulation, Alberta Regulation 173/99, and the Minimum Housing and Health Standards exist in and about the above noted premises, namely:

- a. The living room window had no screen. This is in contravention of section III(2)(b)(iii) of the Minimum Housing and Health Standards which states that: During the portion of the year when there is a need for protection against flies and other flying insects, every window or other device intended for ventilation shall be supplied with effective screens.
- b. The living room was the only sleeping area with a bed. The window was 2.4 square feet which was too small for egress. This is in contravention of section III(3)(b)(i) of the Minimum Housing and Health Standards which states that: Windows referred to above shall provide unobstructed openings with areas not less than 0.35 m² (3.8ft²), with no dimension less than 380 mm (15”).
- c. The bathroom plumbing was in poor repair. This is in contravention of sections IV(6)(b-c) of the Minimum Housing and Health Standards which states that: Adequate water volume and pressure shall be provided to ensure the proper operation and flushing of all fixtures. All plumbing fixtures shall be serviceable, free from leaks, trapped and vented to the outside.
- d. The radiator cover was missing pieces. This is in contravention of section IV(8)(a)(i) of the Minimum Housing and Health Standards which states that: All heating facilities within a housing premises are to be properly installed and maintained in good working condition, and be capable of safely and adequately heating all habitable rooms, bathrooms, and toilet rooms within the building to a temperature of at least 22°C(71°F), or maintained at a temperature of at least 22°C(71°F) when the control of the supplied heat in a dwelling is the responsibility of a person other than the occupant.
- e. The electrical system was in poor repair. This is in contravention of section IV(11) of the Minimum Housing and Health Standards which states that: Every housing premises shall be supplied with electrical service. Outlets, switches and fixtures shall be properly installed and shall be maintained in a good and safe working condition.

- f. The smoke detector was missing. This is in contravention of section IV(12) of the Minimum Housing and Health Standards which states that: Smoke alarms within dwellings shall be installed between each sleeping area and the remainder of the suite and, where hallways serve the sleeping areas; the smoke alarms shall be installed within the hallway. Smoke alarms shall be operational and in good repair at all times.
- g. The unit was very dirty. This is in contravention of section V(16) of the Minimum Housing and Health Standards which states that: The owner shall ensure that all rooms and other areas used in common by the occupants of the individual dwellings are maintained in a clean and sanitary condition.
- h. The unit had rodent activity and harborage. This is in contravention of section V(16)(a) of the Minimum Housing and Health Standards which states that: The owner shall ensure that the housing premises are free of insect and rodent infestations.

AND WHEREAS, by virtue of the foregoing, the above noted premises are hereby declared to be **Closed for Tenant Accommodation Purposes**.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

- 1. That the Owner(s) takes all steps necessary to ensure all Occupants vacate the above noted premises on or before **April 30, 2026**.
- 2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Provide screens on windows used for ventilation.
 - b. Clean the bedroom so that the tenant may sleep there and ensure the window meets egress requirements.
 - c. Repair or replace the bathroom handsink.
 - d. Install all components of the radiators.
 - e. Repair or replace all damaged electrical components. Work should be conducted by a qualified professional.
 - f. Replace the smoke detector.
 - g. End the rodent infestation and all supporting conditions. Remove excess material. Seal rodent entry points. Clean all droppings. Implement an effective pest management plan.
 - h. Clean the entire unit. If the carpet cannot be cleaned, replace it.
 - i. Ensure all the Housing Regulation requirements are met throughout the unit.
- 3. That until such time as the work referred to above is completed to the satisfaction of an Executive Officer of Alberta Health Services; the above noted premises shall remain closed for tenant accommodation purposes.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. **You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations**, or to prevent a public health nuisance.

DATED at Blairmore, Alberta, December 12, 2025.

Executive Officer
Environmental Health Officer

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Copy: Municipality of Crowsnest Pass, Royal Canadian Mounted Police

Order of an Executive Officer – Closed for Tenant Accommodation – Order to Vacate

RE: Those housing premises located in Municipality of Crownsnest Pass, Alberta and municipally described as: Lots: 11-14, Block: 2, Plan: 3319I, 2022 & 2034-129 Street, Blairmore, AB, Unit 3.

Page 5 of 5

PO Box 67, Blairmore, Alberta, Canada T0K 0E0

<https://www.ahs.ca/eph>