

ORDER OF AN EXECUTIVE OFFICER

To: AVENUE LIVING (2014) GP LTD.; Avenue Living Communities Ltd.; Madison Howell;
Mae Cote
“the Owner”

RE: Those housing premises located in Brooks, Alberta and municipally described as: 524 1A
Avenue E, **Unit 209**

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. The backsplash behind the kitchen faucet was replaced with an unpainted fiberboard material that is now water damaged.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Housing Regulation, Alberta Regulation 173/99, and the Minimum Housing and Health Standards exist in and about the above noted premises, namely:

- a. The backsplash behind the kitchen faucet was replaced with an unpainted fiberboard material that is now water damaged. This contravenes section III(5)(b) of the Minimum Housing and Health Standards which states that: All walls, windows, ceilings, floors, and floor coverings shall be maintained in good repair, free of cracks, holes, loose or lifting coverings and in a condition that renders it easy to clean. Rooms and sections of rooms that are used for food preparation and cooking shall have walls and floors constructed of materials which do not provide harbourage to dirt, grease, vermin and bacteria and that are easily kept clean.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Replace backsplash. Seal fiberboard with a paint or primer suitable for kitchen use before installation, and apply caulking at all joints to create a waterproof barrier.
2. The work referred to in paragraph 1 shall be completed by July 18, 2025.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Brooks, Alberta, July 5, 2025.

Confirmation of a verbal order issued to Madison Howell and Mae Cote on June 30, 2025.

Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Template revised April 17, 2024

Order of an Executive Officer

RE: Those premises located in Brooks Alberta and municipally described as: 209 - 524 1A Avenue E

Page 3 of 3

Environmental Public Health – South Zone

440 3rd Street East, Brooks, AB T1R 1B3

www.ahs.ca/eph