

ORDER OF AN EXECUTIVE OFFICER

To: AVENUE LIVING (2014) GP LTD.; Avenue Living Communities Ltd.; Madison Howell;
Mae Cote
“the Owner”

RE: Those housing premises located in Brooks, Alberta and municipally described as: 524 1A
Avenue E, **Unit 308**

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. The living room sliding door screen was broken along the edge of the screen.
- b. Window frames in the two bedrooms showed rust, corrosion, and grime in the seals.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Housing Regulation, Alberta Regulation 173/99, and the Minimum Housing and Health Standards exist in and about the above noted premises, namely:

- a. The living room sliding door screen was broken along the edge of the screen. This contravenes section III(2)(b)(iii) of the Minimum Housing and Health Standards which states that: During the portion of the year when there is a need for protection against flies and other flying insects, every window or other device intended for ventilation shall be supplied with effective screens.
- b. Window frames in the two bedrooms showed rust, corrosion, and grime in the seals. This contravenes section III(2)(b)(i) of the Minimum Housing and Health Standards which states that: All windows and exterior doors shall be; maintained in good repair, free of cracks and weatherproof.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Repair or replace insect screen.
 - b. Replace the window in each of the two bedrooms.
2. The work referred to in paragraph 1 shall be completed by August 1, 2025.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Brooks, Alberta, July 6, 2025.

Confirmation of a verbal order issued to Madison Howell and Mae Cote on June 30, 2025.

Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Template revised April 17, 2024