

ORDER OF AN EXECUTIVE OFFICER NOTICE OF CLOSURE

To: Mandeep Ca “the Owner”
Manwinder Dhillon “the Owner”
Shawn Sinclair “the Operator”

RE: The “whirlpool” located in Lethbridge, Alberta and municipally described as:
The Days Inn by Wyndham Lethbridge
100 3 Avenue S, Lethbridge, AB

WHEREAS I, an **Executive Officer of Alberta Health Services**, have inspected the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. *Pseudomonas aeruginosa* was isolated in the sample collected March 31, 2025.
- b. An HPC of >57000 CFU/mL was isolated in the sample collected March 31, 2025.
- c. *Pseudomonas aeruginosa* was isolated in the sample collected April 7, 2025.
- d. An HPC of >57000 CFU/mL was isolated in the sample collected April 7, 2025.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Public Swimming Pools Regulation, Alberta Regulation 204/2014 and the Pool Standards there under exist in and about the above noted premises, namely:

- a. *Pseudomonas aeruginosa* was isolated in the sample collected March 31, 2025, which is in contravention of Section 6.2 of the Pool Standards which state that the quality of water in a public swimming pool operating at greater than 30 degrees Celsius must be maintained so that samples of the water do not show the presence of *Pseudomonas aeruginosa*.
- b. An HPC of >57000 CFU/mL was isolated in the sample collected March 31, 2025, which is in contravention of Section 6.1(b) of the Pool Standards which state that the quality of water in a public swimming pool must be maintained so that the water does not: have a heterotrophic plate count greater than 100 colony forming units per milliliter in a 100 milliliter sample.
- c. *Pseudomonas aeruginosa* was isolated in the sample collected April 7, 2025, which is in contravention of Section 6.2 of the Pool Standards which state that the quality of water in a public swimming pool operating at greater than 30 degrees Celsius must be maintained so that samples of the water do not show the presence of *Pseudomonas aeruginosa*.

- d. An HPC of >57000 CFU/mL was isolated in the sample collected April 7, 2025, which is in contravention of Section 6.1(b) of the Pool Standards which state that the quality of water in a public swimming pool must be maintained so that the water does not: have a heterotrophic plate count greater than 100 colony forming units per milliliter in a 100 milliliter sample.

AND WHEREAS, by virtue of the foregoing, the above noted premises are hereby declared to be **Closed**.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately **Close** the above noted premises.
2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Drain and clean the whirlpool as per regular Pseudomonas protocols.
 - b. Refill, balance and resample the whirlpool. The whirlpool must stay closed until a sample returns clear of Pseudomonas and total coliforms and the HPC is <100 CFU/mL
3. That until such time as the work referred to above is completed to the satisfaction of an Executive Officer of Alberta Health Services; the above noted premises shall remain closed.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Lethbridge, Alberta, April 10, 2025.

Confirmation of a verbal order issued to Shawn Sinclair on April 10, 2025.

Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW

Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Environmental Public Health – South Zone

Suite 110, 200 – 4 Avenue S Lethbridge, AB T1J 4C9

<https://www.ahs.ca/eph>