

ORDER OF AN EXECUTIVE OFFICER NOTICE OF CLOSURE

To: Pillai Holdings LTD
"the Owner"

RE: The "pool" located in Elkwater, Alberta and municipally described as:
Elkwater Lake Lodge and Resort 401 4 Street, Elkwater, AB, T0J 1C0

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. The pH of the water in the pool is above acceptable parameters to maintain proper disinfection of the swimming pool water.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Public Swimming Pools Regulation, Alberta Regulation 204/2014 and the Pool Standards there under exist in and about the above noted premises, namely:

- a. 14(1) The free chlorine residual level, total alkalinity and pH of the water in a public swimming pool must be sufficient to maintain the water in a bacteriologically safe condition in accordance with the Pool Standards.

AND WHEREAS, by virtue of the foregoing, the above noted premises are hereby declared to be **Closed**.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately close the above noted premises.
2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Correct the pH level of the pool water to no less than 6.8 and no greater than 7.6.
3. That until such time as the work referred to above is completed to the satisfaction of an Executive Officer of Alberta Health Services; the above noted premises shall remain closed.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Medicine Hat, Alberta, 5 June 2023

Confirmation of a verbal order issued to Prabhap Pillai on 2 June 2023.

Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Order of an Executive Officer – Notice of Closure

RE: The Pool located in Elkwater, Alberta and municipally described as: Elkwater Lake Lodge and Resort 401 4 Street

Page 3 of 3

Medicine Hat • River Heights Professional Centre • Environmental Public Health

Suite 200 - 88 Valleyview Drive SW, Medicine Hat, Alberta T1A 8N6

<https://www.ahs.ca/eph>