

ORDER OF AN EXECUTIVE OFFICER NOTICE OF CLOSURE

To: Kevin Owczar
"the Owner"
Cam Randall
"the operator"

RE: The "pool" located in Lethbridge, Alberta and municipally described as:
Superlodge Lethbridge; 2210 7 Avenue S

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. There is no automated chemical feeding system for the pool.
- b. There is no pool permit for this swimming pool.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Public Swimming Pools Regulation, Alberta Regulation 204/2014 and the Pool Standards there under exist in and about the above noted premises, namely:

- a. There is no automated chemical feeding system for the pool which is in contravention of section 15(1) of the Public Swimming Pools Regulation which states that: a public swimming pool must be equipped with automated chemical feeding and monitoring equipment for pH and chlorine.
- b. There is no pool permit for this swimming pool which is in contravention of section 7(1) of the Public Swimming Pools Regulation which states that: No person shall operate a pool without a permit issued in accordance with this section

AND WHEREAS, by virtue of the foregoing, the above noted premises are hereby declared to be **Closed**.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately close the above noted premises.
2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Install an automated chemical feeding and monitoring system for chlorine and pH.
 - b. Apply for a Pool Permit and include the following information:
 - i. a site plan

- ii. a floor plan
 - iii. a structural plan
 - iv. a mechanical plan
 - v. a description of the method of waste water disposal
 - vi. a diagram showing the location and dimensions of the diving, swimming and deck areas, if any
 - vii. the volume of each public swimming pool
 - viii. the maximum design bather load at any given time
 - ix. a description of the type of disinfectant, delivery system, chlorinator capacity, automatic monitoring and feeding equipment
 - x. detailed drawings of the water circulation system, filtration equipment, disinfection equipment and all related equipment
 - xi. a description of:
 1. the filter area, type and rate,
 2. the filtration gauges for measuring pressure change,
 3. the turnover rate,
 4. the rate of flow indicators,
 5. temperature indicators to be installed on the inlet and outlet of all heating equipment,
 6. the number of inlets,
 7. the number of skimmers or gutter drains,
 8. the pool finishes and colour of basin,
 9. the make up water source,
 10. the type of backflow prevention used on the make up water source,
 11. the main drains,
 12. the anti-entrapment devices, including information about the certification of submerged suction outlets, and
 13. the water testing equipment;
3. That until such time as the work referred to above is completed to the satisfaction of an Executive Officer of Alberta Health Services; the above noted premises shall remain closed.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Lethbridge, Alberta, July 24, 2019

Confirmation of a verbal order issued to Kevin Owczar and Cam Randall on July 18, 2019.

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting Alberta Health Services at 780-342-0122 or by contacting the Public Health Appeal Board.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or www.qp.gov.ab.ca.

Health Legislation and regulations are available for purchase. Please contact Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or www.qp.gov.ab.ca.

Copies of standards are available by contacting the Health Protection Branch of Alberta Health at 780-427-4518 or by visiting: www.health.alberta.ca/about/health-legislation.html

Environmental Public Health

801 – 1 Avenue S Lethbridge, AB T1J 4L5

www.albertahealthservices.ca/eph.asp